

# The Gazette of India



## EXTRAORDINARY

### PART II—Section 3

PUBLISHED BY AUTHORITY

NEW DELHI, WEDNESDAY, JANUARY 30, 1957

#### MINISTRY OF WORKS, HOUSING AND SUPPLY

(Central Boilers Board)

#### NOTIFICATION

New Delhi, the 31st December 1956

S.R.O. 345.—The following draft of a further amendment to the Indian Boiler Regulations, 1950, which the Central Boilers Board proposes to make in exercise of the power conferred by section 28 of the Indian Boilers Act, 1923 (V of 1923), is published as required by sub-section (1) of section 31 of the said Act, for the information of all persons likely to be affected thereby; and notice is hereby given that the said draft will be taken into consideration on or after the 1st May 1957.

Any objections or suggestions which may be received from any person with respect to the said draft before the date so specified will be considered by the Central Boilers Board. Such objections or suggestions should be addressed to the Secretary, Central Boilers Board, Ministry of Works, Housing and Supply, North Block, New Delhi.

#### Draft Amendment

In the said Regulations, after Chapter XI the following Chapter shall be inserted, namely:—

#### CHAPTER XII

##### SHELL TYPE BOILERS OF WELDED CONSTRUCTION

535. **Application.**—These regulations shall apply to all boilers of fusion welded construction other than water tube boilers and electrode boilers referred to in Chapters: V and X respectively.

Where the design of the boiler is of composite construction, *viz.*, part fusion welded, part riveted, it shall comply with the relevant regulations governing that particular type of construction.

536. **General Requirements.**—Where applicable the general requirements of Chapter: I relating to certificates from Makers, Inspecting Authorities, and the like and of Chapter III concerning construction, shall be followed.

537. **Materials of Construction.**—Plates, sections and bars used in the construction of these boilers shall comply in all respects with the requirements of Chapter II.

Where, however, the tensile strength exceeds 32 tons per square inch, the full details of the welding technique including pre-heating and post-heating, and the plate preparation to be used, shall be submitted to the Inspecting Authority for approval before manufacture commences.

538. **Covered Electrodes.**—Where covered electrodes are used, they shall comply with the requirements of Regulations: 94—98 save in the case of the welded material where the tensile strength shall not be less than the lower limit specified for the plate.

539. **Plain and Stay Tubes.**—(a) Tubes shall comply so far as may be with the provisions of Regulations 36 to 63.

For plain tubes subjected to external pressure lapwelded steel tubes as provided in the Regulations 64 to 67 may be used.

(b) **Seamless Steel Crosstubes and uptake Tubes.**—Crosstubes and uptake tubes shall comply with Regulations 127 and 128 respectively.

**540. Construction and Workmanship.**—The manufacturer shall supply the Inspecting Authority with a fully dimensioned sectional drawing showing in full detail the construction of the boiler for approval before putting the work in hand.

Full details including dimensions of plate preparation for the longitudinal and circumferential seams shall also be shown on the drawing.

Fully dimensioned sketches showing in details the attachment for standpipes, branch pipes and seatings, the position of these attachments relative to the longitudinal and circumferential seams and other openings shall also be given in the drawing.

**541. Preparation of Plates.**—The edges of all plates shall be machined or flame-cut by machine. Gusset plates may be sheared except on those edges which are to be welded.

Plates which are to be flame-cut by machine without subsequent heat-treatment, grinding or machining, shall not have a carbon content higher than 0·26 per cent. Where the carbon content exceeds 0·26 per cent, heat-treatment, grinding or machining shall be carried out.

The edges of all plates shall have a smooth finish.

The welding edges of all plates shall be cleaned to a smooth metallic surface and shall be free from rust, oil or other foreign matter before welding is commenced.

The surfaces of the plates at the longitudinal and/or circumferential seams shall at no part be out of alignment with one another by more than 10 per cent of the plate thickness but in no case shall the misalignment exceed 1/8 inch for longitudinal seams or 3/16 inch for circumferential seams.

**542. Stress Relieving.**—For the purpose of relieving internal stresses, all plates which have been dished, flanged, or locally heated, shall afterwards be normalised, unless, during the last stage of manufacture they have been uniformly heated throughout.

**543. Cylindrical Shells.**—Except where the design incorporates flat tube plates in the shell, each ring shall be formed from not more than two plates and bent to cylindrical form to the extreme ends of the plate. The bending shall be done entirely by machine. Local heating or hammering shall not be used.

The longitudinal seam or seams may be placed in any suitable position but the seams in successive rings shall not fall in line.

In the case of brick set boilers the seam or seams shall be kept as far as practicable clear of the brickwork.

**544. Circularity.**—The difference between the maximum and minimum internal diameters of the shell measured at any one cross section shall not exceed 1% of the nominal internal diameter.

The profile, as measured on the outside of the boiler by means of a gauge of the designed form of the exterior of the boiler, having a length equal to one quarter of the internal diameter, shall not depart from the designed form by more than the percentage given in Table XII/1.

TABLE XII/1. MAXIMUM PERCENTAGE DEPARTURE FROM DESIGNED FORM OF WELDED BOILERS

Nominal internal diameter of boiler D	Maximum departure from designed form
inches	Per cent of D
Up to and including 36	0.375
Over 36, up to and including 45	0.350
Over 45	0.300

There shall be no flats at the welded seams and any local departure from circularity shall be gradual.

**545. End Plates, Crown Plates and Tube Plates.**—Welded Lancashire and Cornish boilers may have dished or flanged end plates.

(a) The dished end plates of boilers shall be in one piece made from one rolled plate. The flat end plates may be built up from two pieces by fusion butt-welding. In the latter case the line of welding shall be parallel to the

horizontal axis of the boiler and shall run through the centre line of furnace or furnaces of Lancashire and similar types of boilers and between two rows of stays of marine type boilers. In the case of flat end plates the fusion welding shall comply with stress relieving requirements and in the case of dished end plates the fusion welding shall be subjected to both stress relieving and radiographic examination.

(b) The segments for hemispherical shell crown plates shall be pressed in one heat to correct curvature and shall be butt-welded together in accordance with Figures XII/3, XII/4, XII/5 or XII/6. The cylindrical portion of the crown shall be tangential to the hemispherical portion.

Where hemispherical shell crowns are pressed from one plate the provisions of Regulation 547(b) shall apply.

(c) Flanging of plates shall be done by machine. Such flanging shall be done hot, preferably in one operation, but where this is impracticable, creep machine flanging may be used provided that the plate is worked at a suitable temperature and heated for an adequate distance beyond that portion of the plate under immediate treatment.

After completion of the flanging operation flanges shall be of true peripheral contour (either circular or straight as necessary to ensure accurate alignment with the connecting parts), and of good surface, free from bulges, grooves or other local irregularities; flat portions of the plate shall be free from set or distortion.

(d) Where flats are pressed in dished end plates for the attachment of mountings they shall be formed with an ample radius at the junction of the flat and curved surfaces, and shall be free from sharp corners or tool marks; the plate shall not be unduly thinned.

(e) Plates which are flanged in accordance with Regulation 545 (c) shall be welded to the parts to which they are to be connected as follows:

(i) to shells or cylindrical fireboxes as shown in Figures XII/7, XII/8, XII/9, XII/10 or XII/11.

(ii) to internal flue tubes as shown in Figures XII/13, XII/14, XII/15 or XII/16.

(iii) to uptakes as shown in Figure XII/16.

(iv) to combustion chamber or firebox wrapper plates as shown in Figure XII/18.

Plates which are not flanged shall be welded to the parts to which they are to be connected as follows:—

(v) to shells as shown in Figure XII/12.

(vi) to internal flue tubes or uptakes as shown in Figure XII/17.

(vii) to combustion chamber or firebox wrapper plates as shown in Figures XII/19, XII/20 or XII/21.

Where dished ends or crowns are used they shall be flanged for connection to the shell or the cylindrical portion of the firebox. Flat shell and firebox crown plates of vertical boilers shall also be flanged for connection to the cylindrical portions of the shell or firebox.

The opening in the firebox crown plate of a vertical boiler for the uptake shall be flanged and the connection to the uptake made by means of a circumferential butt-weld. (see Figures XII/3, XII/4, XII/5, and XII/6).

**546. Internal Flues.**—(a) Sections of internal flues shall each be made from one plate which shall be bent while cold to circular form. The longitudinal seam shall be forge lapwelded, or fusion butt-welded by the metal arc process.

(b) The maximum permissible variation in diameter of any cross section shall not exceed 1/4 inch or half the thickness of the plate, whichever is the greater.

(c) The longitudinal welds shall be placed at the lower part of the flue and shall break joint in successive sections by at least 12 inches.

(d) Where the flue sections are flanged for circumferential joints the flanging shall be carried out at one heat by suitable machinery.

(e) Edges of all flue flanges shall be machined or flame-cut by machine (see Regulation 541).

(f) Circumferential seams shall be arranged so that they do not fall in line with those of the adjacent flue or with the circumferential seams of the shell and are at least 6 inches apart.

(g) Where at least one-third of the length of a complete flue is corrugated or other suitable means of ensuring longitudinal flexibility are provided, the cylindrical sections (plain and/or corrugated) may be connected to each other by fusion butt-welded circumferential seams.

To provide adequate support for the plain cylindrical portions of the flues, stiffeners having a moment of inertia not less than that required by Regulation 592 (b) shall be securely attached externally by means of continuous welds on each side (see Figures XII/22 and XII/23).

(h) Where a complete flue is constructed of short plain sections, the ends of each adjoining section shall either be swaged out to a radius to provide an adequate point of support and longitudinal flexibility and butt-welded together, or be butt-welded to each side of a bowing hoop. The dimensions shall comply with Figures XII/24, XII/25 or XII/26.

(i) Stress relieving by heat-treatment shall be carried out when the construction of a flue involves the use of a circumferential weld, such stress relieving being carried out on the completion of all welding.

(j) Forms of flue connections to end plates are shown in Figures XII/13, XII/14, XII/15, XII/16 and XII/17.

**547. Fireboxes and Combustion Chambers:** (a) *Furnaces of vertical boilers.*—The furnaces of vertical boilers may be constructed in one or more lengthwise sections, each section being rolled from one plate to a full circle. In such cases, the component sections may be jointed circumferentially by electrical butt-welding. The welding shall be stress relieved.

In the case of vertical boilers where tube plates form part of the firebox, the tube plate portion may be constructed in two vertical sections and the welding of the vertical seams when welded shall be stress relieved.

The maximum permissible variation in diameter, at any cross section shall not exceed  $\frac{1}{4}$  inch for fireboxes upto 3 feet in diameter, or  $\frac{1}{8}$  inch for fireboxes over 3 feet in diameter, or half the thickness of the plate whichever is the greater.

Circular fireboxes shall be tapered, a taper of  $1\frac{1}{4}$  inches in diameter per foot of height being recommended. The water space at the bottom between the firebox and the shell shall be not less than 2 inches for boilers up to and including 2 feet and 6 inches in diameter and shall be not less than  $2\frac{1}{4}$  inches for boilers over 2 feet and 6 inches in diameter.

The method of welding shall be in accordance with Regulation 558.

Flats formed in the firebox for the insertion of water tubes shall have an ample radius at the junction of the flat and the curved surfaces and shall be free from sharp corners or tool marks. The plate shall not be unduly thinned.

Ogee flanging, whether integral with the firebox or made as separate ring shall preferably be formed at one heat by suitable machinery and shall be allowed to cool gradually to avoid internal stresses.

Rings for firehole mouthpieces or foundation rings shall be made of mild steel.

Z sections shall not be used for foundation rings.

Attachment of fireboxes to cylindrical shells shall be in accordance with Figures XII/27, XII/28, XII/29 or XII/30.

The method of attachment of firehole mouthpieces shall be in accordance with Figure XII/31.

(b) *Hemispherical fireboxes.*—Hemispherical fireboxes shall be pressed to form by machine in progressive stages without thinning and shall be annealed on completion.

Methods of attachment of firebox to the shell shall be in accordance with Figures XII/27, XII/28, XII/29 or XII/30.

The method of attachment of firehole mouthpieces and throat pieces shall be in accordance with Figures XII/31 or XII/32.

(c) *Loco-type fireboxes*—Loco-type firebox wrapper plate sides shall preferably be tapered. The water space at the bottom between the firebox and the shell shall be not less than  $2\frac{1}{4}$  inches.

Where the firebox tube plate or firehole plate is flanged for connection to the wrapper plate, the weld shall be located between the commencement of curvature of the flange and first row of screwed stays.

Rings for firehole mouthpieces or foundation rings shall be made of mild steel.

Z sections shall not be used for foundation rings. The attachment of the firebox to the outer casing shall be in accordance with Figure XII/30.

The method of attachment of firehole mouthpieces shall be in accordance with Figure XII/31 or, where the outer casing and the firebox plate are flanged towards the water side to form the firehole, a ring of screwed stays located at not more than half the average pitch of the stays distant from the commencement of the curvature of the flanging shall be provided.

(d) *Water-cooled combustion chambers.*—The attachment of the combustion chamber tube plates and back plates to the wrapper plate shall be in accordance with Figures XII/18, XII/19, XII/20 or XII/21, and where the tube plate or back plate is flanged for connection to the wrapper plate the weld shall be located between the commencement of curvature of the flange and the first row of screwed stays.

The method of attachment of furnace or flue tubes shall be in accordance with Figure XII/15, XII/16 or XII/17 and access openings shall be in accordance with Figure XII/31 or XII/33.

**548. Uptakes.**—The uptakes shall be formed from seamless or hydraulic lap-welded tube, or fusion butt-welded plate, and shall be fusion butt-welded to the upward flange of the opening in the firebox crown plate and the adjacent end of the uptake shall be bevelled in accordance with Figure XII/3 or XII/4. The depth of the flange of the firebox crown plate opening from the commencement of the curvature of the flange shall be not less than twice the plate thickness with a minimum of 1 inch. Unless the whole boiler is to be subsequently stress relieved the uptake and firebox crown plate shall be effectively stress relieved after welding. Where the firebox crown plate is also fusion welded to the body of the firebox as in Figure XII/16, the firebox complete with the uptake shall be effectively stress relieved by heat treatment on completion of all welding.

The uptake may be attached to the shell crown as indicated on Figure XII/17 before the boiler is finally stress relieved by heat treatment.

Where the vertical seam of the uptake is fusion welded the welding shall comply with Regulation 558 and the weld shall be so arranged that it is directly facing the manhole.

It is desirable that the uptake should be fitted with an internal cast iron liner extending below the low water level.

**549. Cross Tubes.**—Cross tubes shall be made from seamless steel tubes.

The tubes shall be of sufficient length to project through the firebox plate not less than  $\frac{1}{4}$  inch or more than  $\frac{1}{2}$  inch at any part of the circumference of the tube. The tubes shall be fusion welded in position, the holes in the firebox plate shall be suitably chamfered, and the seams shall be welded externally and internally (See Figure XII/34).

Cross tubes shall be fusion welded as shown in Figure XII/34.

Projection not less than  $\frac{1}{4}$  inch not more than  $\frac{1}{2}$  inch at any part of circumference of tube.



**FIG. XII/34 FUSION WELDS OF CROSS TUBE.**

**550. Bar stays and Firebox stays.**—Each bar stay or firebox stay shall be made from a solid rolled bar without weld in its length, except where it is attached to the plate it supports.

Bar stays which have been worked in the fire shall be subsequently annealed.

It is preferred that when the stay is in position in the boiler, its axis shall be normal to the plate it supports, but where this cannot be so arranged, then, if the stay is fitted with nuts, bevelled washers shall be provided between the nuts and the plate.

Stays shall be secured to the plates they support by one of the following methods:—

(a) **Bar Stays.**—(i) Plain bars, passing through clearing holes in the plates and welded thereto (See Figure XII/38).

(ii) Plain bars passing through clearing holes in the plates and fitted with washers on the outside, the stay and washers being welded to the plates in accordance with any one of the methods shown in Figures XII/39, XII/40 and XII/41.

(b) **Fire box Stays.**—(i) Screwed stays, screwed through the plates and riveted over at each end to form substantial heads, or fitted with nuts, or the projecting ends fillet-welded as indicated in Figures XII/35, and XII/36.

It is recommended that where the stays are screwed, this shall be with a fine thread and the stays and holes shall be screwed with a continuous thread.

The stays shall be screwed with fine threads of not less than 11 threads per inch.

The screw threads on the stays shall be clean, free from checks or imperfections, of full depth, of a correct standard form and a good fit in the holes.

The middle portion shall preferably be turned down to the bottom of the thread.

(ii) Plain stays shall be strength welded to the plates (see Figure XII/37).

All screwed stays less than 14 inches long should preferably be drilled with a tell-tale hole  $\frac{3}{16}$  inch diameter to a depth of  $\frac{1}{2}$  inch beyond the inner face of the plate. Stays which are obscure on one side should preferably be made from hollow staybar.

**551. Girder stays for Firebox and Combustion Chamber Crowns.**—Where girder stays are attached with stay bolts and nuts, they shall be bedded to the corners or ends of side plates.

The attachment of girder stays welded directly to the crown plates shall comply with Figures XII/42, XII/43, XII/44, XII/45, or XII/46. Such girders shall be welded to the crown plate prior to stress-relieving.

Each girder shall be of sufficient strength to support its due proportion of the load on the crown plate independently of the crown plate, and the bolts or weld attachments shall have sufficient cross-sectional area to carry the applied load.

The waterways between the underside of the girder and the crown plate shall be as large as practicable, but in no case less than  $1\frac{1}{2}$  inches deep.

**552. Gusset stays.**—Gusset stays shall be flat and perpendicular to the end plates. Gusset plates shall not be subjected to cranking or setting.

**553. Access.**—At least one manhole or sight hole shall be provided in the upper part of the boiler, the dimensions being not less than those in Table XII/2 for the given size of boiler:—

TABLE XII/2. Dimensions of Manholes or Sight Holes

Diameter of boiler	Minimum size of hole inches
Boilers not exceeding 2 feet and 6 inches.	9 X 7
Boilers over 2 feet and 6 inches diameter and not exceeding 3 feet.	12 X 9
Boilers over 3 feet diameter and not exceeding 3 feet and 6 inches.	14 X 10
Boilers over 3 feet and 6 inches diameter and not exceeding 4 feet.	15 X 11
Boilers over 4 feet.	16 X 12

Where the size of construction of the boiler does not permit of entry for cleaning or inspection of all internal surfaces, cleaning holes sufficiently large and numerous shall be provided for this purpose. The cleaning holes shall be not less than  $3\frac{1}{2}$  inches  $\times 2\frac{1}{2}$  inches in size.

One cleaning hole shall be provided opposite at least one and of each cross-tube in a vertical crosstube boiler. Where the water tubes are arranged in banks, an opening of sufficient size to permit of their replacement shall be provided.

At the bottom of the narrow water space in vertical boilers where internal access is not possible, mud holes shall be arranged at equal distances round the circumference of the boiler not less in number than as given in Table XII/3.

*Table × 11/3 Number of Lower Cleaning Holes or Mud Holes*

Diameter of boiler.	No. of holes.
2 feet and over but not exceeding 3 feet	.. 3
Over 3 feet and not exceeding 5 feet.	.. 4
Over 5 feet and not exceeding 8 feet.	.. 5
Over 6 feet and not exceeding 7 feet and 6 inches.	.. 6
Over 7 feet and 6 inches and not exceeding 8 feet and 6 inches ..	7
Over 8 feet and 6 inches and not exceeding 9 feet.	.. 8

Cleaning holes or mud holes in loco-type boilers shall be provided at each bottom corner or as nearly as possible in the corners of the outer fire box casing, and at the top corners above firehole opening and also at each corner of the saddle plate in line with the bottom of barrel. Smoke box tube plate shall be provided with a mud hole.

A manhole shall be provided in the lower part of front end plates of Lancashire boilers and in similar boilers with internal flues wherever practicable.

**554. Manhole frames, mouthpieces and doors.**—Manhole frames, mouthpieces, doors or cover plates shall be of mild steel. Frames shall be oval and where of the flanged type shall be formed to bed closely to the shell and provide a flat jointing surface to the door. Alternatively, raised circular mouthpieces may be fitted externally and where of the flanged type shall be bedded closely to the shell.

Wherever practicable, the frame shall be attached to the inside of the shell with the shorter axis parallel to the longitudinal centre line of the boiler. In all cases where the shell thickness exceeds  $\frac{1}{8}$  inch, oval frames or circular mouthpieces shall be fitted.

Doors shall be made from mild steel plate formed to bed closely to the internal surface and shall be fitted with studs each provided with an integral collar and screwed through the plate with a nut on the inside of the door. Doors for openings larger than 9 inches  $\times$  7 inches shall have two studs; but for doors of size 9 inches  $\times$  7 inches, or less only one stud need be fitted; doors for openings not larger than 5 inches  $\times$   $3\frac{1}{2}$  inches may have the stud forged solid with the door.

The cross bars shall be of substantial proportions and either solid steel forging or cast steel. Lugs may be satisfactorily welded to manhole bars for the attachment of the bolts.

The spigots of the door when it is in a central position in the manhole shall have a clearance of not more than  $\frac{1}{8}$  inch all round.

Oval frames and externally raised circular mouthpieces shall be either:—

(a) Formed in piece without weld, or

(b) Formed from a suitable rolled section and forge-welded, of fabricated by fusion welding, provided they are stress-relieved by heat-treatment after welding and before attaching to the boiler unless the whole boiler is subject to heat-treatment on completion.

Welds shall be positioned so that they are located on the transverse centre line of the boiler (See Regulation 556).

The joining flanges of mouthpieces and covers shall be machined on the face and edges and on the bearing surface for the bolts. Bolts and nuts shall be machined where in contact with the flanges and the joints should be formed inside and outside the bolts to preclude the possibility of flange distortion. Cover plates shall be dished outwards to a depth of approximately one-eighth of the internal diameter of the frame.

All edges shall be machined or flame-out by machine (See Regulation 541).

Forms of manhole frames and attachments are shown in Figures XII/47, XII/48, XII/49, XII/50, and XII/51.

**555. Seatings for mountings.**—For pressures not exceeding 125 pounds per square inch mountings with screwed ends not exceeding 1 inch may be used; the screwed portion of any such mounting being an integral part thereof and the thickness at the bottom of the thread being not less than  $\frac{1}{8}$  inch.

The mountings may be screwed:—

Directly into the boiler shell plate, nuts being fitted on the waterside, or

Into steel distance pieces the length of thread engaged being in no case less than the bore of the mounting plus  $\frac{1}{8}$  inch.

The distance pieces shall be made from solid mild steel. They shall be screwed into the plate and fitted with nuts on the water side. The walls of the distance pieces shall be not less than  $\frac{1}{8}$  inch thick at the bottom of the thread.

Mountings may be attached directly to any shell or end plate where the plate is of sufficient thickness to allow a suitable surface to be obtained for the attachment of the boiler mounting.

The minimum thickness at the hole in the shell or end plate shall be not less than the thickness required for the maximum permissible working pressure considering the plate as being unpierced.

Where the boiler mountings are secured by studs the studs shall have a full thread holding in the plate for at least one diameter. If the stud holes penetrate the whole thickness of the plate, the stud shall be screwed right through the plate and be fitted with a nut inside having a thickness equal to the diameter of the stud. Where bolts are used for securing mounting they shall be screwed right through the plate with their heads inside the shell or end plate.

(a) *Standpipes.*—Where standpipes are used, the flanges shall be machined or flame-cut by machine on the edges. The bolting flanges shall be machined on the jointing and bolting surfaces.

(b) *Saddles.*—Where saddles are used, the edges of the flanges shall be machined or flame-cut by machine. The jointing surfaces shall be machined. The studs for the attachment of the mountings, if screwed through the saddle, shall be fitted on the inside with nuts of full thickness.

Where the stud holes do not penetrate through the saddles the length of the screwed portion of the stud in the plate shall be not less than the diameter of the stud.

(c) *Pads.*—Where pads are used, the jointing surfaces shall be machined. The pads shall have sufficient thickness to allow the drilling of the stud holes for mountings without the inner surface being pierced and the length of the screwed portion of the stud in the pad shall be not less than the diameter of the stud.

(d) *Attachment of Standpipes.*—The following constructions as to standpipes attached to shells and end plates shall be permissible:

- (i) When standpipe are screwed, the screwing shall be of standard pipe the standpipe may be screwed into the plate and fitted with a nut on the waterside.
- (ii) Where the internal diameter of the standpipe exceeds one inch but does not exceed 2 inches, it may be screwed in and seal-welded.
- (iii) Where the diameter of the standpipe exceeds 2 inches, it may be welded to the end plate.

The foregoing provisions as to the standpipe attachment shall be regulated by the following conditions:—

- (i) When standpipe are screwed, the screwing shall be of standard pipe thread.
- (ii) Standpipes shall be attached as shown in any one of the Figures XII/80 to XII/85.
- (iii) Where the standpipes are fabricated by fusion welding they shall be stress relieved by heat-treatment before attachment to the boiler.
- (iv) Where the bore of the standpipe does not exceed 5 inches, or the diameter of the opening in the shell does not exceed 5 inches plus

twice the thickness of the plate to which it is attached, the standpipe may be welded to the plate without subsequent heat-treatment of the weld so made. If these limits are exceeded the whole plate to which the standpipe is attached shall be stress relieved by heat treatment on completion of welding.

(e) *Attachment of pads.*—Pads welded to the shell or end plate shall be welded internally or externally.

Methods of attachment of pads shall be as shown in Figures XII/86, XII/87 or XII/88. Where the bore of the seating does not exceed 5 inches or the diameter of the opening in the shell does not exceed 5 inches plus twice the thickness of the plate to which it is attached, the pad may be welded to the plate without subsequent heat-treatment of the weld so made. If these limits are exceeded the whole plate to which the pad is attached shall be stress relieved by heat-treatment on completion of the welding.

(f) *Attachment of water and pressure gauges.*—Water gauges and pressure gauge syphons may be attached direct to the front end plate without the intervention of a pad or standpipe, provided they are flanged and secured by studs. If the studs are screwed through the plate, nuts of full thickness shall be fitted on the inside of the plate.

(g) *Bolts and Nuts.*—All holes for bolts and studs shall be drilled and bolts and nuts shall be machined where in contact with the flanges.

**556. Compensating plates.**—Compensating plates shall be of mild steel and, before attachment, shall bed closely to the plates to which they are to be connected. Any welds therein shall be on the transverse centre line.

**557. Definition of the terms 'Fusion Weld'.**—The terms 'fusion weld' is, for the purpose of this chapter applicable to all welded seams made by the metal arc process with covered electrodes or by any other electric arc process in which the arc stream and the deposited weld metal are shielded from atmospheric contamination.

The relevant provisions of this chapter shall also apply to the single run or heavy run welding process and that welded boilers manufactured by that process shall comply with all regulations of this chapter excepting those in which divergence is necessary solely because of special requirements essential for the most efficient utilisation of that process. Thus all regulations governing quality of material, construction, workmanship, and testing (both non-destructive and otherwise) are applicable.

Where welded shells conforming to the regulations of this Chapter are made by single or heavy run process it shall be understood that Regulations 547, 558 and 559 do not apply in their entirety. The method of making the welds shall be approved by the Inspecting Authority.

**558. Method of Welding.**—The seams shall be fusion-welded from both sides of the plate. The main weld may be on either side of the plate, whichever is most convenient to the manufacturer. Before the second side of the plate is welded, the weld metal at the bottom of the first side shall be removed by grinding, chipping, machining or other approved method.

Additional runs of metal shall be deposited at both surfaces of the welded seams to ensure that the weld metal at the level of the surfaces of the plate is refined as far as possible. The surfaces of the welds which are to be subsequently radiographed shall thereafter be machined or ground so as to provide smooth contours and to be flush with the respective surfaces of the plate. There shall be no under-cutting at the junctions.

The positions of the welds shall be marked permanently to facilitate their location.

When affixing standpipes, branchpipes, seatings, compensation plates, doubling plates or manhole frames, not less than two runs of metal shall be deposited at each weld.

Each run of weld metal shall be thoroughly cleaned and freed from slag before the next run is deposited.

**559. Types of welded shell seams.**—The longitudinal and intermediate circumferential seams shall be made with butt joints of the single or double U or V type (see Figures XII/3, XII/4, XII/5 and XII/6).

End circumferential seams shall be in accordance with Figures XII/7, XII/8, XII/9, XII/10, XII/11 or XII/12.

**560. Repairs to welded seams.**—(a) Any repair to a weld carried out by the manufacturer shall first be agreed to by the Inspecting Authority.

(b) Where defects are distributed over the whole length of the seam the total length of the portions which may be cut out from any one longitudinal or circumferential seam to remove all defects shall not exceed 15 per cent. of the total length of the seam.

When, however, the defects are all located in a single continuous length which may be cut out to remove all defects shall not exceed 10 per cent. of the total length of the seam.

**Circumferential seams.**—Where the length of weld metal cut out for repair in a circumferential seam exceeds the amount stated above the whole of the weld metal shall be removed and the seam re-welded. Representative tests for a re-welded circumferential seam shall be provided when required by the Inspecting Authority.

**Longitudinal seams.**—Where the length of weld metal cut out for repair in any longitudinal seam exceeds the amount stated above, or the weld metal in any other way fails to comply with the requirements specified, the whole of the weld metal shall be removed and the seam re-welded, provided that the original test plates are treated similarly or new plates of the same thickness as the joint and of similar quality of material are attached to the ends of the seam and re-welded with it. In either case the plates are to be tested in accordance with the appropriate provision of Regulation 561 and the requirements for heat-treatment to be in accordance with Regulation 562.

(c) Defects shall be cut out by chipping, machining or other approved methods.

(d) Whenever a defective part has been cut out, the Inspecting Authority shall be notified so that, if necessary, an examination may be made before re-welding.

(e) In the case of Class I boilers all repaired areas shall be subjected to radiographical examination.

(f) The boilers shall be heat-treated on completion of all welded repairs.

**561. Tests on welded seams.**—(a) **Test Plates.**—Test plates to represent all welded seams shall be attached at each end of each longitudinal seam in tension. These shall be of a size sufficient for the preparation of the test pieces specified. In the case of shell plates up to and including 16 feet in length the test plate may be located at one end only (see Figure XII/53). Where the shell is formed in two or more rings, the staggered longitudinal seam shall be regarded as a continuous longitudinal seam provided the welding be effected in one reasonably continuous operation and by the same operator or operators. The material for the test plates shall be cut from the respective plate or plates forming the appropriate seam.

In the case of insufficient material being available on the shell plate to permit the cutting of test pieces, these shall be acceptable if they are made from another plate provided it is made from the same cast. The test plates shall be stamped by the Inspecting Authority before being cut.

The weld groove in the test plates shall be similar to that adopted for the corresponding edges of the longitudinal seam, and the respective fusion faces shall be in continuous alignment. The test plates may be reinforced or supported during welding so that any relative displacement due to warping during welding does not exceed 5 degrees. The weld metal in the test plates and the seam shall be deposited continuously at the same operation.

The weld in any test plate shall not be repaired. If any defects are revealed in the weld metal of a test plate the position of this shall be clearly marked on the plate and the test pieces shall be selected from such parts of the test plates as may be decided by the Inspecting Authority.

Test plates warped during welding by not more than 5 degrees may be straightened before heat-treatment. For the heat-treatment of the test plates see Regulation 562.

Where there are circumferential seams only or where the method of welding the circumferential seams differ from that employed for the longitudinal seams, the method of providing the test plates shall be decided by the Inspecting Authority.

(b) *Class I Tests.*—(i) Specimens for the following tests shall be selected from the test plate or plates and stamped by the Inspecting Officer for identification (see Figures XII/53 and XII/54).

One tensile test specimen for the welded seam.

One all weld metal tensile test specimen.

Two bend test specimens.

Two impact test specimens.

One specimen from each test plate for macro and micro examination.

The dimensions of the specimens shall be in accordance with the sketches in Figures XII/55, XII/56, XII/57 and XII/58. The remainder of the test plates shall be retained for re-tests if required. Any specimen for re-test shall be cut from the same test plate as the original specimen. Specimens representing welded seams shall, if necessary, be straightened cold before the commencement of machining. Tensile and bend specimens shall, if practicable, be of the full plate thickness. Surfaces of tensile, bend and Izod specimens corresponding with the outside or inside of the boiler shall be lightly dressed only so that the rolled surface of the parent metal is not wholly removed. Where the rolled surfaces of the abutting plates are not level with one another, one plate may be machined at each face of the weld so long as the depth of the metal removed does not exceed 1/32 inch.

(ii) *Tensile tests.*—Two test specimens shall be prepared.

The first specimen shall be cut out transversely to the welded seam, and when the capacity of the testing machine does not allow the full thickness of a single specimen to be tested, two narrower tensile specimens shall be substituted. These specimens shall be of the full thickness of the plate at the welded joint and their breadth shall be as great as the testing machine will reasonably allow, providing the effective cross sectional area of the test piece is not less than 1½ square inches. (See Figure XII/55, Specimens 1a and 1b). The tensile strength shall not be less than the lower limit specified for the plate.

The second specimen shall consist entirely of deposited metal and shall be cut out longitudinally from the seam (see Figure XII/57). The tensile strength shall not be less than the lower limit specified for the plate. The elongation shall not be less than 20% on a gauge length or four times the square root of the cross sectional area of the specimen, and the reduction in area not less than 35%.

(iii) *Cold bend tests.*—Two bend tests shall be made.

One specimen shall be tested with the outer surface of the weld in tension, and the other with the inner surface in tension. The specimens shall be rectangular in section and shall be cut out transversely to the weld so as to have a width not less than one-and-a-half times the thickness of the plates. The sharp corners of the specimens shall be rounded to a radius not exceeding 10% of the thickness of the specimen.

Where the plate thickness does not exceed 1½ inches, the thickness of the specimen shall be equal to the full thickness of the test plate. Where the plate thickness exceeds 1½ inches, the specimen shall in all cases have a thickness of at least 1½ inches. The specimen to be tested with the outer surface of the weld in tension shall be prepared by cutting to waste the metal local to the inner surface of the weld, so that the desired specimen thickness is obtained (see A, Figure XII/58).

The specimen to be tested with the inner surface in tension shall be prepared by cutting to waste the metal local to the outer surface of the weld so that the desired specimen thickness is obtained (see B, Figure XII/58). Where the thickness of the plate permits, both specimens may be cut from the same piece of plate, the specimens being located in the plate one above the other (see C, Figure XII/58). Each specimen shall be mounted with the weld midway between the supports set apart at a distance of not more than 5.2 times the thickness of the specimen and pushed through the supports with a former having a diameter equal to three times the thickness of the specimen.

On completion of the test no crack or defect at the outer surface of the specimen shall be greater than 1/16 inch measure across the specimen or  $\frac{1}{4}$  inch measured along the length of the specimen. Premature failure at corners of the specimen shall not be considered cause for rejection.

(iv) *Impact tests.*—Two rectangular specimens shall be cut out transversely to the welded joint and they shall conform to the dimensions shown in Figure XII/56.

One specimen shall have the notch cut at the middle of the outer surface of the weld, and the other at the middle of the inner surface of the weld.

The tests shall show a minimum Izod impact test value of 20 foot pounds, the test being carried out at a temperature between 50°C. (122°F) and 100°C. (212°F.).

(v) *Macro-and Micro-examinations.*—A specimen the full thickness of the plate and not less than half-an-inch wide shall be provided from each set of test plates for the purpose of macro-and micro-examinations.

(vi) *Additional Tests before rejection.*—Should any of the test specimens taken in accordance with this Regulation fail to meet the specified requirements, re-tests shall be allowed for each specimen that fails as follows:—

Where any result of the tensile test is not less than 90% of the specified figures one re-test shall be made. Where any result falls below 90%, two re-tests shall be made.

Where a bend specimen fails to meet the specified requirements, two re-tests shall be made.

If an impact test fails to meet the specified requirements, two re-tests shall be taken from the test plate, one on each side of the original specimen and separate from it by not more than 5 millimetres.

If it be found there is insufficient metal to permit the preparation of specimens for re-test from the remainder of the test-plate from which the original specimen was taken, the specimen for re-test may be cut from the test plate relating to the opposite end of the same longitudinal seam.

Should any of the additional tests fail to meet the specified requirements the welded seams represented by these tests shall be rejected.

(vii) *Specimens after test.*—If required the specimens after test shall be at the disposal of the Inspecting Authority for examination.

(viii) *Radiographic examinations.*—Every portion of the longitudinal and circumferential welded seams of the shell of the boiler shall be subjected to radiographic examination.

The methods employed in obtaining the radiographs shall be such as to show clearly differences equal to 2% of the thickness at the welded joint. To determine whether this result is being attained an indicator of approved form which includes a portion equivalent to not more than 2% of the joint thickness shall be placed in the vicinity of the weld so as to make a record on each radiograph.

Each section of every weld shall be marked so that the radiographs can be easily correlated to the particular part of the seam represented.

The examination shall be made from the original films and the acceptability of the welds shall be decided by the Inspecting Authority. The welds deemed unsatisfactory shall be rejected or dealt with under the condition of Regulation 560 and be radiographed again. The films shall be retained by the manufacturer for a reasonable period for reference and be available to the Inspecting Authority if required.

(c) *Class II Tests.*—(i) From each longitudinal seam test pieces shall be selected for the following tests and stamped by the Inspector for identification.

From the test plate or plates:—

One tensile test specimen for welded seam.

One bend test specimen.

One reverse bend test specimen.

One nick-break test specimen.

One Micro and Macro test specimen from each test plate.

The disposition of the specimen shall be in accordance with the sketches in Figure XII/59. The remainder of each test plate shall be retained for re-tests if required.

(ii) **Tensile test.**—The dimensions of the test specimen shall be in accordance with the sketch in Figure XII/55, Specimen 1a, and the specimen shall be cut out transversely to the welded seam. When the capacity of the available testing machine does not allow the full specimen to be tested, two narrower tensile specimens shall be substituted. These specimens shall be the full thickness of the plate at the welded joint and their breadth shall be as great as the testing machine will reasonably allow, provided the effective cross sectional area of the test piece is not less than  $1\frac{1}{2}$  square inches (see Figure XII/55, Specimen 1b). The tensile strength of the welded joint specimen shall be not less than the lower limit specified for the plate.

(iii) **Cold bend tests.**—Two bend tests shall be made.

One specimen shall be tested with the outer surface of the weld in tension, and the other with the inner surface in tension. The specimens shall be rectangular in section and shall be cut out transversely to the weld so as to have a width not less than one-and-a-half times the thickness of the plate. The sharp corners of the specimens shall be rounded to a radius not exceeding 10% of the thickness of the specimen.

The specimen to be tested with the outer surface of the weld in tension shall be prepared by cutting to waste the metal local to the inner surface of the weld, so that the desired specimen thickness is obtained. (See A, Figure XII/58). The specimen to be tested with inner surface in tension shall be prepared by cutting to waste the metal local to the outer surface of the weld so that the desired specimen thickness is obtained. (See B, Figure XII/58). Where the thickness of the plate permits both specimens may be cut from the same piece of plate, the specimens being located in the plate one above the other. (See C, Figure XII/58).

Each specimen shall be mounted with the weld midway between the supports set apart at a distance of not more than 5.2 times the thickness of the specimen and pushed through the supports with a former having a diameter equal to three times the thickness of the specimen.

On the completion of the test no crack or defect at the outer surface of the specimen shall be greater than  $1/16$  inch measured across the specimen, or  $\frac{1}{8}$  inch measured along the length of the specimen. Premature failure at corners of the specimen shall not be considered cause for rejection.

(iv) **Nick-break specimen.**—This specimen shall have a width not less than one-and-a-half times its thickness and the slot shall be cut in each side of the specimen through the centre of the weld and perpendicular to the outer face of the boiler.

The specimen shall then be broken in the weld and the fracture shall reveal a sound homogeneous weld substantially free from slag inclusions, porosity and coarse crystallinity.

(v) **Macro and Micro Examinations.**—A specimen the full thickness of the plate and not less than  $\frac{1}{4}$  inch wide shall be provided from each set of test plates for the purpose of Macro and Micro examinations.

(vi) **Additional tests before rejection.**—If any of the test specimens should fail, two re-tests shall be made and both shall meet the specified requirements.

(vii) **Specimens after tests.**—If required, specimens after tests shall be at the disposal of the Inspecting Authority for examinations.

**562. Heat Treatment.**—All boilers shall be stress relieved by heat-treatment after completion of all welding and before hydraulic test.

The heat treatment furnace should be sufficiently large to accommodate the whole boiler. The furnace temperature shall be slowly raised to between 600°C. and 650°C. and the boiler shall remain until it has uniformly reached this temperature which shall be maintained for a period of not less than one hour per inch of plate thickness. The boiler should be allowed to cool slowly in the furnace but if withdrawn shall be effectively screened from draughts.

During heat treatment the official test plates shall be inside the boiler. Where the shell is subjected to a primary stress relieving treatment identical to the final heat treatment to be given to the boiler, the test plates may be placed inside the shell during primary treatment and thereafter cut up and tested without waiting for the final treatment of the boiler.

Where the shell is not subjected to primary stress relieving treatment or is subject to a primary stress relieving treatment which is not identical with the final heat treatment the test plates may be placed inside any other boiler of comparable dimensions which is to be heat treated in accordance with this Chapter.

Temperature charts shall be submitted to indicate that the test plates and the boilers they represent have been subjected to identical heating, soaking and cooling treatment.

Alternative procedure for the heat treatment of any boiler may be submitted to the Inspecting Authority for approval.

**563. Classification of Fusion-Welded Boilers.**—The boilers covered by this Chapter shall be classified in accordance with Table XII/3.

TABLE XII/3  
*Classification of Fusion-Welded Boilers*

Classification	Limits of application	Minimum thickness
Class I	No limit	$\frac{1}{4}$ inch.
Class II	When the following limits are not exceeded: a. Design pressure—105 pounds per square inch. b. Design pressure in pounds per square inch multiplied by internal diameter in inches = 5250.	Boilers up to and including 36 inches internal diameter— $\frac{1}{4}$ inch. Boilers over 36 inches internal diameter— $\frac{1}{2}$ inch.

**564. Shells.**—The working pressure of the cylindrical shell shall be determined by the following formula:

$$WP = \frac{(t-2) S C}{D}$$

Equation XII/I

where—

t is minimum thickness of shell plate in thirty-seconds of an inch.

WP is working pressure in pounds per square inch.

D is maximum Internal diameter in inches.

S is minimum tensile strength of plate in tons per square inch.

C is a constant, as given below.

In no case, however, shall the factor of safety of the shell be less than 4 or the plate thickness be less than specified in Table XII/3 given under Regulation 563.

C=32 where Class I requirements are complied with.

C=27 where Class II requirements are complied with.

Where boilers have a nest or nests of horizontal tubes, so that there is a direct tension on the tube plates due to the vertical load on the boiler ends or to tube plates acting as horizontal ties across the shell.

(i) each alternate tube in the outer vertical rows of tubes shall be a stay tube.

(ii) the thickness of the tube plates and the spacing of the tubes shall be such that the section of metal taking the load is sufficient to keep the stress within that allowed on the shell plate, as determined by the following formula:—

$$WP = \frac{(t-2) S J}{z. 9 D} \dots\dots$$

Equation XII/2

where—

$t$  is thickness of the tube plate in thirty-seconds of an inch.

WP is working pressure in pounds per square inch.

S is minimum tensile strength of plate in tons per square inch.

D is twice the radial distance of the centre of the outer row of tube holes from the axis of the shell in inches.

J is the percentage strength of the plate through the tube holes, i.e.,

$$= \frac{100(p-d)}{p} \quad \dots \dots \text{Equation XII/3.}$$

$p$  is the vertical pitch of tubes in inches.

$d$  is the diameter of the tube holes in inches.

NOTE.—The tube plates between the stay tubes shall comply with the requirements for tube plates (see Regulation 577).

**565. Horizontal shelves of tube plates forming part of the shell.**—The number of gussets required to support the horizontal shelves of tube plates to withstand the vertical load due to the pressure on the boiler ends shall be determined in the following manner:—

For combustion Chamber tube plates the minimum number of the gussets shall be—

Where C exceeds 4560	..	..	..	1 gusset.
Where C exceeds 6240	..	..	..	2 gussets.
Where C exceeds 7440	..	..	..	3 gussets.

For the smoke box tube plate the minimum number of gussets shall be:—

Where C exceeds 4560	..	..	..	1 gusset.
Where C exceeds 8400	..	..	..	2 gussets.

and  $C = \frac{ADP}{t}$

Equation 4

where—

$A$  is maximum horizontal dimension of the shelf from the inside of the shell plate to the outside of the tube plate, in inches.

$D$  is inside diameter of the boiler in inches.

P is working pressure in pounds per square inch.

$t$  is thickness of tube plate in thirty-seconds of an inch.  
(see figure XII/61).




FIG. XII/61.

The shell plates to which the sides of the tube plates are connected shall be not less than  $1/16$  inch thicker than is required by the formula applicable to shell plates with continuous circularity; and where gussets or other stays are not

fitted to the shelves the strength of the parts of the circumferential seams at the top and bottom of these plates from the outside of one tube plate to the outside of the other, shall be sufficient to withstand the whole load on the boiler end, with a factor of safety of not less than 4·5.

**566. Dished end plates for Lancashire and Cornish boilers.**—The dished ends of Lancashire and Cornish boilers with external or internal flanges for furnaces without stays and subject to internal pressure the maximum working pressure shall be determined by the following formula:—

$$WP = \frac{(1-8) \times 30 \times S}{R} \quad \text{Equation XII/5}$$

where—

t is minimum thickness of the end plate in thirty-second of an inch.

WP is working pressure in pounds per square inch.

R is inner radius of curvature of the end plate in inches.

S is minimum tensile strength of the plate in tons per square inch.

The inner radius of curvature of the end plate shall not exceed  $1\frac{1}{2}$  times the external diameter of the shell to which it is attached.

The inner radius of flanging of the end plate shall be not less than 4 times the thickness of the plate but in no case less than  $2\frac{1}{2}$  inches.

Where the end plate has a manhole, compensation shall be obtained by flanging the edge of the opening or by providing a fabricated ring (see Figure XII/47).

In either case the depth of the flanging or ring measured at the minor axis shall not be less than that determined by the following formula:—

$$D = \sqrt{T W} \quad \dots \dots \quad \text{Equation XII/6}$$

where—

D is depth of flange or ring in inches—measured from the outside of the plate to the joint face.

T is thickness of the plate in inches.

W is width of the opening in inches—measured on the minor axis.

**567. Dished ends subject to internal pressure.**—For unstayed ends of shells and tops of vertical boilers and the like boiler parts, when dished to partial spherical form the maximum working pressure shall be determined by the following formula:—

$$WP = \frac{15 \times S \times (t - 1)}{R} \quad \dots \dots \quad \text{Equation XII/7}$$

WP is the working pressure in pounds per square inch.

t is thickness of the end plate in thirty seconds of an inch, but in no case this shall be less than the thickness of the shell to which it is attached.

R is the inner radius of curvature of the end in inches, which shall not exceed the external diameter of the shell to which it is attached.

S is the minimum tensile breaking strength of plate in tons per square inch, or whatever is allowed for it.

(b) The inside radius to which a crown plate is dished shall be not greater than the external diameter of the cylinder to which it is attached.

(c) The inside radius of curvature of the flanges to the shell shall be not less than 4 times the thickness of the crown plate and in no case less than  $2\frac{1}{2}$  inches.

(d) The inside radius of curvature of flanges to uptakes shall be not less than twice the thickness of the crown plate and in no case less than 1 inch.

(e) When the end has a manhole in it (t=5), shall be substituted for (t-1) in the formula.

(f) The total depth of flange of manhole from the outer surface in inches measured on the minor axis shall be at least equal to—

$$\sqrt{T \times W} \quad \text{depth of flange in inches} \quad \text{Equation XII/8}$$

where T is the thickness of the plate in inches and W is the minor axis of the hole in inches.

(g) The depth of the crown plate opening from the commencement of the curvature of the flanging radius shall be not less than twice the plate thickness or a minimum of one inch.

**568. Dished ends subject to external pressure.**—In the case of unstayed dished ends, for the coefficient 15 in Equation XII/8, the coefficient 12 shall be substituted, where  $R$  shall be the outer radius of the curvature of plate, which shall not exceed the external diameter of the shell to which it is attached.

For plates exposed to furnace-flame the coefficient shall be 10·5. In no case

$$\text{If } \frac{R}{t} \text{ exceed } 2\cdot75.$$

The inside radius of curvature at the flange shall be not less than 4 times the thickness of the end plate and in no case less than  $2\frac{1}{2}$  inches.

The inside radius of the curvature of the flange to uptake shall be not less than twice the thickness of the crown plate and in no case less than one inch.

**569. Hemispherical crowns.**—The maximum working pressure for hemispherical crowns subjected to internal pressure shall be determined by the following formula:—

$$WP = \frac{(t - 2) S \times C}{R} \quad \dots \dots \text{Equation XII/9}$$

where

$t$  is thickness of plate in thirty-seconds of an inch.

$WP$  is the working pressure in pounds per square inch.

$R$  is inner radius of curvature in inches.

$S$  is minimum tensile strength of the plate in tons per square inch.

$C$  is a constant, as given below.

In no case, however, shall the factor of safety of the crown plate be less than 4 or the plate thickness be less than specified in Table given under Regulation 563.

$C=32$  where Class I requirements are complied with.

$C=27$  where Class II requirements are complied with.

**570. Manholes and other openings in shells.**—Manholes and other openings in shells shall be placed as far as possible from any seam. Wherever practicable all openings shall be arranged with the minor axis parallel with the longitudinal centre line of the boiler. In no case shall the circumferential length of any opening exceed twice the longitudinal width of the opening.

**571. Compensation for openings in shells.**—Where the width of any opening measured in a direction parallel to the longitudinal axis of the boiler exceeds one-and-a-half times the thickness of the shell plate in inches plus  $2\frac{1}{2}$  inches, compensation shall be provided.

(a) **Area to be compensated.**—The area to be compensated shall be the product of the maximum width of the opening cut in the shell and the thickness of an unpierced seamless shell of similar material calculated by Equation XII/I with constant  $C=35$  for the same working pressure.

(b) **Compensating area.**—Compensation shall be considered adequate when the sum of the following areas is not less than the area to be compensated:—

(i) The area obtained by multiplying the difference between the actual thickness of the shell and the thickness required for an equivalent unpierced seamless shell by a length  $2(3\text{ inch}+T_s)$ , where  $T_s$  is the actual thickness of the shell plate in inches.

(ii) The net cross sectional area of the frame or pad, or in the case of a branch the cross sectional area of the wall of the branch minus the sectional area of a branch of the same bore having thickness equal to that calculated by Equation XII/I for the same working pressure (with constant  $C=35$  if seamless),  $s$  is the thickness required to withstand external loads. The areas shall be measured within limits such that  $(a+b)$  in Figure XII/62 does not exceed inches.

Where the material of a frame, pad or branch has a tensile strength which differs from that of the shell to which it is attached, the compensating area shall be multiplied by the ratio:

Tensile strength of compensating part.

Tensile strength of shell plate.

(iii) The cross sectional area of the welding fillets.

(c) **Compensating plates.**—In cases where the sum of (i), (ii) and (iii) is less than the area to be compensated, a compensating plate shall be welded to the shell, its total cross sectional area being equal to the amount of the deficit due allowance being made as above when the tensile strength of the mate of the plate differs from that of the shell.

Notwithstanding compliance with the requirements of paragraph (b) however, a reinforcing plate shall be fitted around all branches of 4 inches bore or over welded to shell plates having a thickness of  $\frac{1}{2}$  inch or less.

The compensating plate may be fitted on the inside or outside of the shell plate as most convenient and its diameter shall not exceed twice the longitudinal width of the opening in the shell.

(d) Figure XII/62 shows a welded branch to which the foregoing requirements apply where,

W is width of the opening in the shell in inches.

T<sub>s</sub> is actual thickness of shell in inches.

T<sub>1</sub> is thickness of an equivalent unpierced seamless shell calculated by Equation XII/1 with C=35, in inches.

T<sub>r</sub> is actual thickness of branch in inches.

T<sub>2</sub> is minimum thickness of body of branch calculated by Equation XI (with C=35 if seamless) in inches.

T<sub>3</sub> is thickness required to withstand external loads in inches.— $\frac{1}{2}$  inch until the loading is shown to be such as to require a greater thickness O where there is no external loading.

T<sub>c</sub> is minimum thickness of compensating plate in inches.

S<sub>1</sub> is minimum tensile strength of shell plate in tons per square inch.

S<sub>2</sub> is minimum tensile strength of branch in tons per square inch.

S<sub>3</sub> is minimum tensile strength of compensating plate in tons per square inch.

w is width of compensating plate in inches measured in the same plane as the shell opening.

*Area to be compensated.*

$$A = W \times T_r$$

*Compensating area.*

(i) Portion of shell available for compensation:—

$$B = 2(3 + T_s)(T_s - T_1)$$

(ii) Portion of branch available for compensation:—

$$C = 2(4 + T_s)[T_n - (T_2 + T_3)] \times \frac{S_2}{S_1}$$

(iii) Portion of welds available for compensation:—

D=Total cross sectional area of the internal and external welding fillets.

If A is greater than (B+C+D), additional compensation is required to make up the difference. In the example shown in Figure XII/62 this is provided by means of a compensating plate, the total compensating area being such that (B+C+D)+Z is not less than A where—

$$Z = 2 \times w \times T_c \times \frac{S_3}{S_1}$$

**572. Raised manhole frames, cover plates and joint bolts.**—Raised circular manhole frames not exceeding 16 inches in diameter shall not be less than  $\frac{1}{2}$  inch thick in all parts.

The circular cover plates and joint flanges for such frames shall be not less than—

1 inch thick for pressures not exceeding 120 pounds per square inch.

$1\frac{1}{2}$  inches thick for pressures exceeding 120 pounds per square inch but not exceeding 200 pounds per square inch.

$1\frac{1}{4}$  inches thick for pressures exceeding 200 pounds but not exceeding 250 pounds per square inch.

For pressures exceeding 250 pounds per square inch, raised circular manholes shall not be fitted.

The cover plates shall be secured by at least sixteen steel bolts not less than 1 inch diameter, such that the stress in the bolts due to steam pressure shall not exceed—

5,000 pounds per square inch for 1 inch bolts.

6,000 pounds per square inch for 1½ inches bolts.

6,500 pounds per square inch for 1¾ inches bolts.

For the purpose of calculation, the pressure shall be assumed to act on the whole area within the pitch circle of the bolts and the bolt area at the bottom of the screw thread shall be taken.

**73. Standpipes.**—The thickness and bolting of all flanges joining mountings shall be not less than that required by Appendix E, "Tables of pipe flanges", for appropriate pressure, but in no case shall the thickness be less than ½ inch.

(a) For pressures up to 360 pounds per square inch the minimum thickness of standpipes fabricated by fusion welding shall be determined by the following formula:—

$$t = D + 6 \dots \text{Equation XII/10.}$$

where  
t is thickness of standpipe in thirty seconds of an inch.

D is external diameter of standpipe in inches.

Solid forged standpipes shall have a minimum thickness of flange and body in accordance with Table XII/4.

TABLE XII/4  
*Thickness of solid forged standpipes*

Diameter of standpipe	Minimum thickness				Design pressure above 260 upto and including 360 pounds per square inch	
	Design pressure upto and including 160 pounds per square inch		Design pressure above 160 and upto and including 260 pounds per square inch			
	Flange joining boiler	Body	Flange joining boiler	Body	Flange joining boiler	Body
inches	inches	inches	inches	inches	inches	inches
1	7/16	3/8	1/2	3/8	3/4	3/8
1½	7/16	3/8	1/2	3/8	3/4	3/8
1¾	7/16	3/8	1/2	7/16	3/4	1/2
2	7/16	3/8	9/16	7/16	3/4	1/2
2½	7/16	3/8	9/16	7/16	7/8	5/8
3	9/16	7/16	5/8	1/2	7/8	5/8
3½	9/16	7/16	5/8	1/2	7/8	5/8
4	9/16	7/16	5/8	1/2	7/8	5/8
4½	9/16	7/16	5/8	1/2	7/8	5/8
5	5/8	9/16	3/4	5/8	7/8	5/8
6	5/8	9/16	3/4	5/8	7/8	5/8
7	5/8	9/16	3/4	5/8	7/8	5/8
8	5/8	9/16	3/4	5/8	7/8	5/8
9	5/8	5/8	3/4	5/8	7/8	5/8
10	5/8	5/8	3/4	5/8	7/8	5/8
Pressed plate saddle 5/8 inch		Pressed plate saddle 3/4 inch		Pressed plate saddle 7/8 inch		

(b) Where a double flanged standpipe is tapered, the thickness of the flange joining the boiler shall correspond to the bore at that flange in accordance with Table XII/4.

**Note.**—It may be necessary to increase the thickness obtained from Table X or Equation XII/10 to allow for external loading.

**574. Stayed flat surfaces (other than crowns of vertical boilers).**—(a) Where flat end plates are flanged for connection to the shell, the inside radius of flange shall be not less than 1.75 times the thickness of the plate with a minimum of  $1\frac{1}{2}$  inches.

(b) Where combustion chamber or fire-box plates are flanged for connection to the wrapper, the inside radius of flanging shall be equal to the thickness of plate, with a minimum of 1 inch.

(c) Where the flange curvature is a point of support, this shall be taken at commencement of curvature, or at a line  $3\frac{1}{2}$  times the thickness of the plate, measured from the outside of the plate, whichever is nearer to the flange.

(d) Where a flat plate is welded directly to a shell or wrapper, the point support shall be taken at the inside of the shell or wrapper.

(e) The working pressure of flat plates supported by stays, shall be determined by the following formula:

$$WP = \frac{C(t-1)^2}{A^2 + B^2} \dots \text{Equation XII/II.}$$

where

t is thickness of plate in thirty-seconds of an inch.

WP is working pressure in pounds per square inch.

A is horizontal pitch of stays in inches.

B is vertical pitch of the stays in inches.

**C** is Constant, as given below:

The constants given below relate to plates which are stress relieved and exposed to flame.

When plates are exposed to flame the constants shall be reduced by 12½ cent.

Where various forms of support are used Constant C shall be the mean of values for the respective methods adopted.

Where stays are irregularly pitched,  $D^2$  shall be taken instead of  $A^2$ .  
D being the diameter in inches, of the largest circle which can be drawn in  
the circumference passing through three points of support without enclosing  
another point of support. No more than two points of support may be located  
one side of any diameter of the circle.

The value of the Constant C in Equation XII/11 shall be as follows:

(i) Where stays are screwed through the plates and, in addition, are welded to the plates on the outside, the size of the weld being 0.25 of the diameter of the screwed portion of the stay (see Figure XII/35):—

C-57.

(ii) Where stays are screwed through the plates and, in addition, are welded to the plates on the outside the size of weld being 0.35 of the diameter of the screwed portion of the stay (see Figure XII/36):—

C=80

(iii) Where plain stays are strength welded into the plates (see Fig XII/37):—

C-80

(iv) Where plain bar stays pass through holes in the plates and are secured thereto by fillet welds on both sides of the plates (see Figure XII/38):—

C-85

(v) Where plain bar stays pass through holes in the plates and are fitted the outside with washers having a diameter equal to two-and-one-quarter times

the diameter of the stay and a thickness of not less than  $\frac{3}{8}$  inch, the stay being fillet welded to the plate inside and to the washer outside, the edge of the washer being secured to the plate by a fillet weld not less than  $\frac{3}{16}$  inch. (See Figure XII/39):

$$C=95$$

(vi) Where plain bar stays pass through holes in the plates and are fitted on the outside with washers having a diameter equal to three-and-one-half times the diameter of the stay and a thickness of at least two-thirds that of the plate, the stay being fillet welded to the plate inside and to the washer outside, the edge of the washer being secured to the plate by a fillet weld not less than  $\frac{3}{16}$  inch. (See Figure XII/40):

$$C=110$$

(vii) Where plain bar stays pass through holes in the plates and are fitted on the outside with large washers having a diameter equal to two thirds of the pitch of the stays and a thickness of at least two-thirds that of the plate, the stay being fillet welded to the plate on the inside and strength welded to the washer and plate outside, the edge of the washer being secured to the plate by a full fillet weld, (see Figure XII/41):—

$$C=120$$

Note:—In cases (iv), (v) and (vii) above, the fillet welds securing the stay bars to the plates or washers shall be at least equal to one-quarter the diameter of the stay.

(viii) Where the flat plate is flanged for attachment to the shell, flue or wrapper [see Regulation 574(c)]:

$$C=110$$

(ix) Where the flat plate is welded directly to the shell, flue or wrapper [see Regulation 574(d)]:

$$C=110$$

(x) Where the support is a gusset or link stay:

$$C=80$$

(xi) For the lower portion of the front end plate of a Lancashire boiler containing the manhole, the values of D and C to be used in Equation XII/11 shall be as follows:—

D=diameter in inches of the largest circle which can be drawn enclosing the manhole and passing through the points of support formed by the gusset stays and the connections to the shell and furnaces. Where the circle passes through only three of the possible five points of support mentioned, the remaining two shall be included within the circle.

$$C=300$$

(xii) In Cornish boilers where it is necessary to strengthen the portion of the end plate outside the wing gussets, suitable section stiffeners shall be secured to the plates by full fillet welds within the circle D, and the appropriate constant C shall be increased by 30 per cent. The stiffeners shall be placed in such a position, and the section used shall be such, that:—

- (i) The unstayed area will be approximately equally divided.
- (ii) The load will be transmitted at each end as directly as possible to the gusset stays or other supporting boundaries.
- (iii) The thickness of the vertical rib of any tee bar stiffener shall be not less than the thickness of the end plate.

(f) In the case of smaller boilers where the end plates are supported in the steam space by a single substantial tee bar (continuously fillet welded to the plate with not less than  $\frac{1}{4}$  inch, fillet welds) extending across the plate to the commencement of curvature of the flange or the toe of the fillet weld securing the end plate to the shell, or where such plates are supported with a deep bulb

extending across the plates as described above, the thickness of the plate shall be determined by Equation XII/11 the values of D and C being as follows:—

(i) For the portion of the plate above the stiffeners:

D is diameter in inches, of the largest circle passing through the centre of the tee or bulb and the commencement of flange curvature or the inside of the shell, whichever is applicable:

$$C=80$$

(ii) For the portion of the plate below the stiffeners:

D is diameter in inches of the circle passing through the centre of the tee or bulb and two adjacent screwed stays:

$$C=55$$

or

D is diameter in inches of the circle passing through the centre of the tee or bulb and the centre line of the top row of tubes:

$$C=35$$

**575. Flat crown plates for vertical boilers.**—Flat crown plates shall be supported by the uptake and/or bar stays. The inside radius of curvature of the flange to the shell or firebox shall be not less than four times the thickness of the plate and in no case less than  $2\frac{1}{2}$  inches where the plate is flanged for attachment to the uptake the inside radius of curvature of the flange shall be not less than twice the thickness of the plate and in no case less than 1 inch. The thickness of flat crown plates shall be determined by Equation XII/11, D<sup>2</sup> being substituted for A<sup>2</sup>+B<sup>2</sup>, and C being defined as follows:

Where the crown plate is supported by an uptake only D is diameter of the largest circle which can be drawn between the connections to the shell or fire box and uptake, in inches (see Regulation 574 a, b, c, d):

$$C=55$$

Where bar stays are fitted in accordance with Regulations 587 and 588, D is diameter of the largest circle which can be drawn through support, in inches.

C is the mean of the values for the respective point of support through which the circle passes (see Regulation 574).

**576. Wide water spaces between and around tube nests.**—Except as specified in Regulation 577 stay tubes shall be fitted in the tube nests. The working pressure of the tube plate in the wide water space between tube nests shall be determined by the following formula;

$$WP = \frac{C(t-l)^2}{A^2 + B^2} \dots \text{Equation XII/12.}$$

where

t is thickness of the tube plate in thirty-seconds of an inch.

WP is working pressure in pounds per square inch.

A is width of the wide water space between the tube nests in inches (measured at the centre line of the stay tubes).

B is pitch of the stay tubes in the boundary rows of the wide water space, in inches.

Where the stay tubes are welded to the tubeplates in accordance with Figure XII/65 with tubes lightly expanded before welding:

C=56 if the plates are exposed to flame.

C=64 if plates are not exposed to flame.

Where the stay tubes are welded to the tubeplates in accordance with Figure XII/65 with tubes lightly expanded before welding:

C=70 if the plates are exposed to flame.

C=80 if the plates are not exposed to flame.

Where the stays are irregularly pitched  $D^2$  shall be taken instead of  $(A^2 + B^2)$  where D is the diameter of the largest circle which can be drawn through any three points of support without enclosing another point of support (See Figures XII/66, XII/67 XII/68, XII/69, XII/70, XII/71, XII/72 and XII/73) Where various forms of supports are used, the value of C shall be the mean of the values for the respective methods adopted. At the attachment of the end plate to shell, furnaces of flues, the point of support and the constant C to be used shall be taken in accordance with Regulation 574.

For the portions of the end plates between the top rows of tubes and the steam space stays, Equation XII/12 shall apply, B being taken as the distance between the centre line of the top rows of tubes and the centre of the bar stays or other point of support and A being taken as

$$\frac{A_1 + A_3}{2}$$

where

$A_1$  is the distance between the centres of bar stays or other method of support, and

$A_2$  is the horizontal distance from the centre of one stay tube and the centre of the next stay tube in the top boundary row. Where no stay tubes are fitted  $A_2$  shall be taken as equal to four times the horizontal pitch of the plain tubes. Where no stay tubes are fitted the support afforded by the plain tubes shall not be taken to extend beyond the line enclosing the outer surfaces of the tubes except that between the outside of the wing row of tubes and the attachment of the end plate to shell, there may be an unsupported width equal to the flat plate margin as given by Equation XII/17.

577. Parts of flat tube plates within tube nests.—(a) Where the total area of all tube nests in directly fired multitubular boilers exceeds 7 square feet, stay tubes shall be fitted.

Where the total number of tubes in horizontal multitubular waste heat boilers and direct fired loco-type boilers is arranged in one nest, the area of which exceeds 21 square feet, stay tubes shall be fitted.

In all cases, where the total number of tubes is arranged in more than one nest, stay tubes shall be fitted.

The working pressure of the tubeplates within the tube nests shall be determined by the following formula:

#### Where stay tubes are fitted

$$WP = \frac{C(t-1)^2}{M^2} \dots \dots \text{Equation XII/13.}$$

where

t is thickness of the tubeplate in thirty-seconds of an inch.

WP is working pressure—pounds per square inch.

M is mean pitch of the stay tubes in inches--being the sum of the four sides of any quadrilateral bounded by four quadrilaterals adjacent stay tubes divided by 4.

C is 56 for plates exposed to flame.

64 for plates not exposed to flame.

Stay tubes secured in accordance with Figure XII/63 or XII/64.

C=70 for plates exposed to flame.

C=80 for plates not exposed to flame.

Stay tubes secured in accordance with Figure XII/65.

(b) Where the area of the tube nest does not exceed 7 square feet in the case of direct fired boilers or 21 square feet in the case of waste heat boilers, and stay tubes are not fitted, the ends of all tubes may be welded at the gas inlet end and welded or expanded at the outlet end.

Alternatively, the tubes may be expanded and beaded at the inlet end, and expanded at the outlet end. In both cases the working pressure of the tube plate

shall be determined by Equation XII/13, where  $M =$  four times the mean pitch in inches of the plain tubes in the nest.

$C = 50$  for plates exposed to flame.

$C = 60$  for plates not exposed to flame.

**578. Manhole openings in flat plates.**—Where manholes are located in flat plates, the openings shall be suitably compensated.

Compensation shall be obtained by flanging the edge of the opening, or by providing a fabricate ring (see Figures XII/47, XII/48, XII/49, XII/50 and XII/51).

The manhole in the lower portion of the flat front end plates shall be fitted with a flanged strengthening ring, the thickness of the flat portion of which shall be not less than  $(1:3T + \frac{1}{8}$  inch) where  $T =$  the thickness of the end plate in inches, and in boilers of 7 feet and 8 inches diameter and over the manhole frame shall be fitted with a peak to reinforce the portion of the end plate between and below the furnaces and this peak shall be securely welded thereto.

In all cases the depth of the flanging or ring shall not be less than that determined by Equation XII/6.

**NOTE:**—Where the manhole is located in or between tube nests in multitubular boilers or below the furnaces of other Boilers the stay tubes in the boundary rows, or the gusset stays, as applicable, shall be arranged as closely as practicable to the manhole.

**579. Plain tubes.**—(a) *Attachment.*—Plain tubes may be welded at both ends, welded at the inlet end and expanded at the outlet end, or expanded at both ends.

Where the tubes are expanded only, the process shall be carried out with expanders having parallel rollers, and the expanded portion of the tube shall be parallel through the full thickness of the tube-plate. In addition to expanding, tubes may be bell-mouthed or beaded at the inlet end.

Where the tube is welded to the tubeplate, the tube should be lightly expanded to grip the tube hole before welding.

(b) The maximum working pressure for the tube subject to the external pressure shall be:

$$WP = \frac{100(t-6)}{D} \quad . . . . . \quad \text{Equation XII/14.}$$

where

$t$  is thickness of the tubes in one hundredths of an inch.

$D$  is external diameter of the tubes in inches.

No tube shall be less than 12 S.W.G. ( $0:104"$ ) thick.

(c) The working pressure of tubes subjected to internal pressure shall be determined by the following formula:

$$WP = \frac{140(t-10)}{D} \quad . . . . . \quad \text{Equation XII/15.}$$

where

$t$  is minimum thickness of tubes in one hundredths of an inch.

$WP$  is working pressure in pounds per square inch.

$D$  is outside diameter of tubes in inches.

**580. Pitch of tubes.**—The spacing of tube holes shall be such that the minimum width in inches of any ligament between the tube holes shall be not less than:

$$\frac{D}{8} + \frac{t}{8}$$

alternatively,

the thickness and cross-section of the plate between the tube holes shall be not less than

$$0.125D + 0.2 = \text{minimum thickness in inches}$$

$$0.17D + 0.025 = \text{minimum cross-section in square inches where } D \text{ is diameter of the tube hole in inches.}$$

In no case shall the minimum thickness of any tube plate in the tube area be less than the following limits:—

$$T = \frac{1}{4} \text{ inch.}$$

where the diameter of the tube hole does not exceed 2 inches;

$$T = \frac{9}{16} \text{ inch.}$$

where the diameter of the tube hole is greater than 2 inches.

**581. Stay tubes.**—Stay tubes shall be of steel, seamless or electrically welded (see Regulation 539).

The maximum working pressure for stay tubes shall be calculated by the following formula:

$$WP = \frac{5500}{A} \left[ \left( D - \frac{1.28}{N} \right)^2 - D_1^2 \right] \quad . . . . . \text{Equation XII/16}$$

D is diameter of the stay tube over threads in inches.

$D_1$  is internal diameter of the tube under the threads in inches.

N is number of threads per inch.

The thickness of stay tubes at any part shall be not less than  $\frac{3}{16}$  inch.

Where stay tubes have their thickness increased at the screwed ends to provide for plus threads, the increased thickness shall be obtained by upsetting and not by welding, and the tubes shall be subsequently annealed.

Stay tubes may be attached to the tube plates either by screwing or by metal arc welding.

Where stay tubes are screwed into the tube plates they shall be screwed with a continuous thread not finer than 11 threads per inch at both ends and shall be expanded into the tube plates, by roller expander and, if desired, may be seal welded.

Attachment of stay tubes shall be as shown in Figures XII/63, XII/64 and XII/65.

**582. Compression of tube plates.**—(a) For fire-box or combustion chamber tube plates which are subject to compression due to the pressure on the roof plate, the maximum working pressure shall be:

$$WP = \frac{C \times (P - D) \times t}{L \times P} \quad . . . . . \text{Equation XII/17}$$

t is thickness of the tube plate in thirty seconds of an inch.

P is pitch of the tubes in inches, measured horizontally where the tubes are chain pitched, or diagonally where the tubes are zigzag pitched and the diagonal pitch is less than the horizontal.

D is internal diameter of the plain tubes in inches,

L is internal length of the fire-box or combustion chamber in inches measured at top between tube plate and firehole plate or back plate, or between tube plates in double ended boilers with combustion chambers common to two opposite furnaces.

$$C=875.$$

Provided that the above formula shall not apply in the cases of fireboxes where the girders do not rest on the tube plate, or where the roof plate is stayed direct to the outer shell or to girders supported by the shell.

(b) Where girders rest on the side plates or the roof plate is so formed that the load is carried both by side and end plates, the compressive stress on the plates shall not in either case exceed 14,000 pounds per square inch.

**583. Girders for firebox and combustion chamber crowns.**—(a) For girders supporting crown plates of rectangular fireboxes, where the ends of the girders are supported by the vertical end or side plates, their proportions shall be calculated by the following formula:

$$WP = \frac{C S T d^3}{L^4 Y} \quad . . . . . \text{Equation XII/18}$$

Where

WP is Working pressure in pounds per square inch,

S is Minimum tensile stress of the material in tons per square inch,

T is Total thickness of the stay in thirty seconds of an inch,

d is Depth of the girder stay in inches,

L is Length of girder stay in inches measured between the inside of the tube plate and the firehole plate, or between the inside of the side plates, according to the method of support,

Y is Pitch of girder stays in inches,

C=22 for steel plates or steel forgings,

=19 for steel castings.

(b) Where girders are welded to the crown plate the dimensions of the welds shall be such that the stress calculated on an area equal to the sum of the effective lengths of the welds attaching each girder multiplied by the effective throat thickness shall not exceed 7500 pounds per square inch multiplied by the appropriate weld factor in Table XII/7. ("effective length" and "effective throat thickness" are defined in Regulation 581). The load on the welds shall be taken as that due to the design pressure acting on the area LY; L and Y being as defined in Regulation 583.

**584. Girder sling stays.**—For slung girders the proportion of slings, links, pins and connections to the shell shall be sufficient to carry the whole load that would otherwise be carried on the toes of the girders and for any of the above parts in tension a stress of 9,000 pounds per square inch of net section, and for parts in shear a stress of 8,000 pounds per square inch of net section shall not be exceeded. In the case of parts in double shear, the net area of the section should be taken as 1.875 times the single section.

**585. Stays for fire-boxes and circular furnaces.**—(a) **Solid screwed stays.**—For screw stays to combustion chambers and fire boxes and for longitudinal and cross stays, the maximum working pressure for the stays is to be calculated from the appropriate one of the following two formulae:—

$$W.P. = \frac{C}{A} \left( D - \frac{1.28}{N} \right)^2 . \quad \text{Equation XII/19}$$

$$W.P. = \frac{C \times D^2}{A} . \quad \text{Equation XII/20}$$

W.P. is the working pressure in pounds per square inch,

D is diameter of stays over threads in inches,

D, is diameter of body of stay at its smallest part in inches,

N is number of threads of stay per inch.

A is area in square inches supported by one stay for area to be supported by stays near tubes in firebox tube plates of locotype boilers, See Regulation 193(a),

C=7100 for steel or special wrought iron screw stays to combustion chamber or fire-boxes,

C=8640 for steel longitudinal or cross stays fitted with nuts,

C=4700 for cooper stays.

Where stays are made with enlarged ends and the body of the stay is smaller in diameter than at the bottom of the thread the working pressure shall be calculated from the second formula.

(b) **Circumferential stays for circular furnaces and fire boxes.**—The diameter of the stay shall be not less than  $\frac{1}{4}$  inch or twice the thickness of the firebox plate, whichever is the greater. In the case of screwed threads the diameter shall be measured over the threads.

The pitch of the stays at the firebox shall not exceed 14 times the thickness of the firebox plate.

**586. Firebox Crown Stays for Loco-type Boilers.**—Where firebox crown stays are directly attached to a semi-cylindrical outer casing, and the firebox top is thickened and fitted with stays, arranged as shown in Figure XII/74, the thickness of the outer casing shall be sufficient to provide not less than three engaging threads, of which not less than one shall be full thread in stays not normal

to the stayed surface, but if the thickness of the plate is not sufficient to give one engaging full thread the plate shall be reinforced.

Where vertical stays only are used to take part of the load on the firebox top, boilers with shells 4 feet and 6 inches diameter and over shall be fitted with transverse stays (see Figure XII/75). Stays may be attached as shown in Figure XII/35, XII/36 or XII/37.

**587. Longitudinal Bar Stays.**—The maximum working pressure for longitudinal bar stays is to be calculated from the appropriate one of the following two formulae:—

$$\text{W.P.} = \frac{C}{A} \left( D - \frac{1.28}{N} \right)^2 \quad \dots \dots \text{Equation XII/21}$$

$$\text{W.P.} = \frac{C \times D^2}{A} \quad \text{XII/22}$$

W.P. is working pressure in pounds per square inch,

D is diameter of stays over threads in inches,

$D_1$  is diameter of body of stays at its smallest part in inches,

N is the number of threads of stay per inch,

A is area in square inches supported by one stay,

C is values given in Table below:

• TABLE XII/5

*Stress on Longitudinal Bar stays*

Range of tensile strength of bar	Value of C
tons per square inch	pounds per square inch
26/30	7850
28/32	8640
30/34	9420
32/36	10200

Where bar stays are fitted in vertical boilers, not less than four bar stays shall be fitted to boilers of 4 feet and over but under 5 feet in diameter; five bar stays to boilers of 5 feet and over but under 6 feet in diameter; six bar stays to boilers of 6 feet and over in diameter.

In no case, shall the diameter of the stay at any part be less than 1 inch. Where joined stays are fitted, the strength of the knuckle joint employed shall be at least equal to the strength of the remainder of the bar stay.

**588. Loads on Stay Tubes and Bar Stays.**—Stay tubes and bar stays shall be designed to carry the whole load due to the pressure on the area to be supported, the areas being calculated as follows:—

(a) For a stay tube within the tube nest the net area to be supported shall be the product of the horizontal and vertical pitches, in inches, of the stay tubes less the area of the tube holes embraced. Where the pitch of the stay tubes is irregular the area shall be taken as the square of the mean pitch of the stay tubes (i.e., the square of 1/4 of the sum of the four sides of any quadrilateral bounded by four adjacent staytubes), less the area of the tube holes embraced.

(b) For a stay tube in the boundary raw, or for a bar stay, the net area to be supported shall be the area, in square inches enclosed by lines passing midway between the stay and the adjacent points of support and by the boundary margin (see Regulation 589), less the area of any tubes or stays embraced.

(c) In the case of a bar stay where there are no stay tubes in the tube nest the area to be supported shall extend to the tangential boundary of the tube nest.

**589. Flat Plate Margins.**—The amount of support in relief of the stays which may be attributed to the shell, furnaces or flues to which flat plates are attached, shall not exceed that determined by the following formulae.

$$\text{Width of margin in inches} = \frac{C(t-1)}{\sqrt{W.P.}} \quad \dots \text{Equation XII/23}$$

t is plate thickness in thirty-seconds of an inch,

W.P. is working pressure in pounds per square inch,

C=3.47 for plates exposed to flame,

C=3.70 for plates not exposed to flame.

Where the plates are flanged, the margin shall be measured from the commencement of curvature of flanging, or from a line  $3\frac{1}{2}$  times the thickness of the plate measured from the outside of the plate, whichever is nearer to the flange. Where the flat plate is not flanged for attachment to the shell or flue tubes and is welded as shown in figure XII/12 or XII/17, the width of the margin shall be measured from the inside of the shell or the outside of the flue tube, whichever is applicable.

In no case, however, shall the diameter D of the circle forming the boundary of the margin supported by the uptake of a vertical boiler be greater than that found by the following formula:—

$$D = \frac{5000A}{\sqrt{W.P.}} + \frac{d^2}{4} \quad \dots \text{Equation XII/24}$$

A is cross sectional area of the uptake tube in square inches,

W.P. is working pressure in pounds per square inch,

d is external diameter of uptake in inches.

**590. Breathing Space.**—Gusset stays shall be arranged to give sufficient bearing space around the furnace, connections and tube nests (see Figures XII/66, XII/67, XII/68, XII/69). The proportions shown in Table 8 are recommended for the portion of the end plates above the furnaces and the flues:—

TABLE XII/6

*Breathing Space*

Thickness of end plate	Dimension 'L'
inches.	inches
1/2	10
9/16	11
5/8	12
11/16	13
3/4	13
13/16	13
Over 13/16	13. 1/2

The breathing space below the flues shall be approximately one half the dimensions given in Table XII/6.

For gusset stays above the tube nests, as fitted in multitubular waste heat boilers without internal furnaces, a bearing space of 8 inches from the centre line of the adjacent tubes to the toe of the gusset angle or plate, may be maintained. For the back end stays below the furnaces of multitubular dryback boilers a breathing space of 6 inches may be maintained where the flues are constructed in accordance with Regulation 846.

Where the flues are constructed of corrugated sections welded together, a breathing space of  $4\frac{1}{2}$  inches may be maintained.

**591. Gusset and Link Stays.**—For welded Lancashire, Cornish and cylindrical horizontal multitubular type boilers, all-welded gusset stays shall not be used. To ensure flexibility link stays, bar stays or suitably designed gusset stays other than the all-welded type shall be used. All-welded gusset stays, however, be used in cylindrical horizontal waste heat and cylindrical vertical multitubular boilers.

(a) *Load on each stay.*—Each gusset or link stay supporting the flat end plate of a boiler shall be designed to carry the whole load due to pressure on the area it supports. The area supported by any one stay shall be obtained by considering the total area to be supported which lies within the limits of the flat plate margins and dividing this area by boundary lines drawn between the stays. These boundary lines shall be at all points equidistant from the adjacent points of support in the area under consideration.

The effective uniformly distributed load on a triangular gusset plate or on a diagonal link stay shall be assumed to be equal to the perpendicular load on the portion of the end plate to be supported (determined as above) multiplied by  $L/L_1$  (see figures XII/77, XII/78 and XII/79).

(b) *Gusset plates.*—Gusset plates shall be so proportioned that the angle "V" (see Figures XII/77 and XII/78) is not less than  $60^\circ$ .

The thickness of the gusset plate shall be such that the stress in the plate to withstand the effective uniformly distributed load (as defined above) calculated on the smallest cross section on Line XX or YY (Figures XII/77 and XII/78), shall not exceed one-seventh of the minimum tensile stress of the plate used but in no case shall the thickness be less than seven-eighths of the thickness of the shell, plate with a minimum of  $7/16$  inch.

Where all-welded gusset stays are used a stiffening plate shall be welded at the toe of the gusset where it is secured to the end plate (i.e., where the maximum stress occurs) (see Figure XII/77).

(c) *Link stays.*—Link stays shall be so arranged that the angle "V" (Figure XII/79) is not less than  $60^\circ$  and the dimensions shall be such that the stress in the stay at its weakest part does not exceed one-seventh of the minimum tensile stress of the plate used.

(d) *Anchor plates, angles, link pins and the like members.*—The strength of anchor plates, angles and link pins calculated at the weakest section shall be as follows:—

(i) Link pins shall be so designed that the shear stress does not exceed 8,000 pounds per square inch, the strength of pins in double shear being taken as 1.875 times the strength of pins in single shear.

(ii) Anchor plates or angles shall be so designed that the calculated stress does not exceed one-seventh of the minimum tensile stress of the material used, but in no case shall the thickness be less than seven-eighths of the thickness of the shell plate with a minimum of  $\frac{1}{4}$  inch, nor the length of the portion attached to the end plate be less than the distance between the lines of end to shell flat margin and the breathing space line around the flues or tube nests.

(e) *Weld attachments.*—Where gusset plates, anchor plates or angles are welded to the shell and/or end plates, the attachment shall be by means of continuous fillet welds on each side or by butt welds prepared in accordance with Paragraph 2, details l, m, n, or p of Appendix A of this Chapter.

The welds shall be of such dimensions that the stress calculated on an area equal to the effective length of the weld multiplied by the effective throat thickness shall not exceed that permitted for the parent metal multiplied by the appropriate weld factor in Table XII/7.

The effective length of a weld shall be taken as that length of weld which is of the specified size throughout.

For open-ended fillet welds the effective length shall be the overall length less twice the weld size.

For the purpose of stress calculation the effective throat thickness of a butt weld shall be taken as the thickness of the gusset or anchor plate and the effective throat thickness of fillet weld shall be taken as 0.7 of the fillet size. For compound welds the effective throat thickness shall be the sum of those of the constituent parts.

TABLE XII/7—WELD ATTACHMENTS

Form of weld		Weld factor
Single J or bevel butt welds (with or without superimposed fillet)	Unsealed Sealed	.45 .70
Double J or bevel butt welds (with or without superimposed fillet (s).		.70
Double fillet welds.		.65

592. **Furnaces and Flue Sections of Horizontal Boilers.**—(a) Plain furnaces: The working pressure of plain furnaces shall be the lesser of the two obtained by the use of the following two formulae:—

$$W.P. = \frac{1450}{D} \times \frac{(t-1)^2}{L+24} \quad \dots \dots \dots \text{Equation XII/25}$$

$$W.P. = \frac{50}{D} [10(t-1)-L] \quad \dots \dots \dots \text{Equation XII/26}$$

$t$  is minimum thickness of plate in thirty seconds of an inch.

$D$  is external diameter of furnace or flues in inches.

WP is working pressure in pounds per square inch.

$L$  is length of section in inches between centres of points of substantial support (see Figures XII/22, XII/23, XII/24, XII/25 and XII/26).

The thickness of any plain furnace or flue section shall not exceed  $\frac{1}{4}$  inch, or be less than  $\frac{1}{8}$  inch.

(b) **Stiffeners.**—Where stiffeners are used as shown in Figures XII/22 and XII/23, the moment of inertia of the stiffener shall be not less than that required by the following formula:—

$$I = \frac{0.14 D^3 PL}{E} \quad \dots \dots \dots \text{Equation XII/27.}$$

where

$D$  is external diameter of flue in inches.

P is working pressure in pounds per square inch.

$L$  is length of section in inches between centres of points of substantial support.

E is modulus of elasticity in pounds per square inch, at the design temperature of the metal ( $27.8 \times 10^6$ ).

I is moment of inertia in inches<sup>4</sup> of stiffening ring about its neutral axis.

(c) **Loco type firebox crowns.**—Where loco type firebox crown are made with a large radius at each side, as in Figure XII/75, the crown shall be provided with stiffeners as shown. The number of stiffeners or points of support shall be determined by Equations XII/25, XII/26, and the moment of inertia of the stiffeners by Equation, taking  $D$  as  $2R$  in Figure XII/75.

(d) **Corrugated furnaces of horizontal boilers.**—The maximum working pressure to be allowed on corrugated furnaces shall be determined by the following formula:—

$$W.P. = \frac{C}{D} (t-1) \quad \dots \dots \dots \text{Equation XII/28.}$$

WP is working pressure in pounds per square inch.

D is the least external diameter in inches measured at the bottom of the corrugations of the waterside.

this thickness of the furnace plate in thirty seconds of an inch measured at the bottom of the corrugation or chamber.

C=480 for the Fox, Morrison, Deighton, Purves, and other similar furnaces and 510 for the Leeds Forge Bulb suspension Furnace.

No corrugated furnace shall be more than 7/8 inch or be less than 3/8 inch thick. The depth of corrugations plus the thickness of the plate shall be not less than 2 inches.

**593. Plain Furnaces of Vertical Boilers.**—The maximum working pressure of Plain Furnaces of Vertical boilers shall be the lesser of the two values obtained by equations XII/25 and XII/26

where

D=external diameter of the firebox in inches. Where the firebox is tapered the diameter taken shall be the mean of that at the top and at the bottom where it meets the substantial support from the flange or ring.

L is length of the firebox in inches between points of substantial support, measured from the commencement of flange curvature, or from the foundation connection, or from a row of screwed stays which comply with Regulations 550(a), 585(b) whichever is applicable.

In no case, however, shall the thickness be more than 7/8 inch. For fireboxes under 2 feet and 6 inches in diameter, the thickness shall be not less than 5/16 inch and for fireboxes 2 feet and 6 inches in diameter and over, the thickness shall be not less than 3/8 inch.

**594. Corrugated Fireboxes of Vertical Boilers.**—For the semi-spirally corrugated fireboxes of 'Sentinel' standard motor wagon boilers the working pressure shall be determined by the following formula:—

$$W.P. = \frac{C(t-1)}{D} \dots \text{XII/29.}$$

W.P. is working pressure in pounds per square inch.

t is thickness of the fire box plate in thirty seconds of an inch.

D is mean of the external diameters of firebox measured over the plain part at each end at commencement of curvature of flange.

C=390.

No corrugated furnace shall be less than 3/8 inch thick.

**595. Hemispherical Furnaces of Vertical Boilers.**—When furnaces are hemispherical in form and subject to pressure on the convex side and are without support from stays of any kind, the maximum working pressure shall be found by the following formula:—

$$W.P. = \frac{275(t-1)}{R} \dots \text{Equation XII/30.}$$

W.P. is working pressure in pounds per square inch.

t is thickness of the top plate in thirty seconds of an inch.

R is outer radius of curvature of the furnace in inches.

The thickness of these furnaces shall in no case exceed 7/8 inch.

**596. Foundations of Vertical Boiler Furnaces.**—When circular furnaces of fireboxes of vertical boilers are not connected to the shell crown by uptake tube, smoke tubes or bolt stays and the whole load on the firebox vertically is borne by the bottom part of the firebox where it is connected to the shell the working pressure for the part, if firebox is joggled out to meet the shell or if any ogee ring is fitted, shall not exceed that found by the following formula:—

$$W.P. = \frac{C(t-1)^2}{D(D-D_1)} \dots \text{Equation XII/31.}$$

W.P. is working pressure in pounds per square inch.

$t$  is thickness of the joggled firebox plate or ogee ring in thirty seconds of an inch.

$D$  is inside diameter of the boiler shell in inches.

$D$ , is outside diameter of the joggled firebox at the commencement of curvature above joggled part or the outside diameter of the firebox where it joins the ogee ring.

$C=140$  for Ogee rings (see Figures XII/27 and XII/28).

$C=100$  where 'U' ring section is used (see Figure XII/29).

**597. Foundations of Loco-type Boiler Fireboxes.**—Where the firebox roof in loco-type boilers is not stayed direct to the external casing crown or to girders carried by the casing or if not connected to the casing by slings, the working pressure for the parts, if plates are joggled out to meet the casing or if an ogee ring is fitted, shall not exceed that found by the following formula:—

$$W.P. = \frac{70 (t-1)^2 x (L+W)}{L x W (W-W_1)} \quad \text{Equation XII/32.}$$

WP is working pressure in pounds per square inch.

$t$  is thickness of the joggled firebox side plates or fire hole plate (whichever is less), a ogee ring in thirty seconds of an inch.

$L$  is length of firebox casing in inches measured between the water sides of front end plate and saddle plate at the foundation seam.

$W$  is width of firebox casing in inches measured between the water sides of casing side plates at the foundation seam.

$W_1$  is width of firebox in inches measured between the water sides of firebox side plates at the commencement of curvature above joggled part or where it joins the ogee ring.

Where only a comparatively narrow strip of the firebox roof is stayed directly to the casing crown the area so stayed shall be deducted from the area represented by  $L \times W$  in the bottom line of the formula thus  $(L \times W-A)$  ( $W-W_1$ ) and so used in Equation XII/32 in determining the working pressure for the parts, "A" being the area in square inches of the part of roof supported by the casing crown.

**598. Uptakes of Vertical Boilers.**—The working pressure for uptake tubes of vertical boilers shall be determined by the following formula:—

(i) When an internal liner is not fitted:—

$$W.P. = \frac{100 (t-2)}{D} \quad \text{Equation XII/33.}$$

(ii) When an internal liner is fitted extending below the low water level:—

$$W.P. = \frac{725}{D} \times \frac{(t-1)^2}{(L+24)} \quad \text{XII/34.}$$

where

W.P. is working pressure in pounds per square inch.

$t$  is thickness of the uptake in thirty seconds of an inch.

$D$  is external diameter in inches.

$L$  is length of the uptake in inches, measured between the circumferential seams.

In no case shall the thickness of an uptake tube be less than 3/8 inch.

**599. Cross Tubes.**—Internal diameter of cross tubes shall not exceed 12 inches. The working pressure of the tubes shall be determined by the following formula:—

$$W.P. = \frac{200 (t-7)}{D} \quad \text{XII/35.}$$

$t$  is thickness in thirty seconds of an inch.

$D$  is internal diameter in inches of the cross tube.

In no case shall the thickness of a cross tube be less than 5/16 inch.

**600. Pads Welded to shell for the attachment of Flanged Mountings.**—(See Figure XII/86).—The size of outer peripheral fillet welds by which circular pads are attached to shell plates shall be determined by the following formula XII/36, but shall in no case be less than the inner welds nor less than the minimum specified for plate thickness in Table XII/3:—

$$L_o = \frac{2A - D_o L_i}{D_o} \dots \text{Equation XII/36.}$$

where

$L_o$  is size of fillet weld around outer periphery of pad, in inches.

$L_i$  is size of fillet weld around inner periphery of pad, in inches.

$A$  is cross sectional area of opening in shell (based on minimum thickness) in square inches (see Regulation 571).

$D_o$  is outer diameter of pad in inches.

$D_i$  is inner diameter of pad in inches.


**601. Hydraulic and Hammer Tests.**—(a) **Class I Boilers.**—Each Class I Boiler shall, on completion of all welding and/or repairs and after heat-treatment, be subjected to a hydraulic test of  $1\frac{1}{4}$  times the working pressure and while under this pressure, the welds shall be given a thorough hammer test throughout their length. The pressure shall then be released and afterwards raised to  $1\frac{1}{2}$  times the working pressure + 50 pounds per square inch and steadily maintained for a length of time sufficient to enable an inspection to be made of all seams and connections, but for not less than half-an-hour.

(b) **Class II Boilers.**—Each Class II Boiler shall after heat treatment, be subjected to the same form of test as for Class I Boilers, except that every Boiler shall be given a hammer test and the hydraulic pressure to be applied for the test shall be  $1\frac{1}{2}$  times the working pressure. This pressure shall be released and then raised to twice the working pressure.

During Hammer test care should be taken to avoid damage to the surface of the plate.


Should the hydraulic test reveal any defect in the welded seam it shall not be repaired unless agreed upon by the Inspecting Authority.

On completion of agreed repairs to the boiler which has previously been stress relieved by heat treatment this treatment shall, if required by the Inspecting Authority, be repeated and the boiler shall again be subjected to the hydraulic test.

**"ADDENDUM"**

$L = 8(T_2 - T_1)$  BUT  
NOT LESS THAN  $1\frac{1}{2}$  IN.


FIG. XII/1





WHERE  $(T_2 - T_1)$  DOES  
NOT EXCEED  $\frac{1}{8}$  IN.

FIG. XII/2

CROSS SEAMS IN ENDPLATES.









FIG. XII/9

FLANGED ENDPLATES,  
ENDS THICKER THAN SHELL



DIFFERENCE ( $TS - TE$ ) NOT TO EXCEED  
20 PER CENT OF  $TS$ .

FIG. XII/10 FLANGED FLAT END PLATES.





FIG. XII/11 FLANGED FLAT END PLATES.

END PLATES TO SHELL (SHELL THICKER THAN ENDS)






FIG. XII/13




FIG. XIV/4

FLUE CONNECTIONS TO END PLATES  
(DISHED OR FLAT)




FIG. XII/15




FIG. XII/16.








FIG. XII/17

FIG. XII/18FIG. XII/19FIG. XII/20FIG. XII/21

ATTACHMENT OF END PLATES TO  
COMBUSTION CHAMBER ENDS OR  
FIRE BOX WRAPPER PLATES.




FIG. XII/22  
PLAIN BAR




FIG XII/23  
BULB BAR

STIFFENERS FOR HORIZONTAL FLUES.






FIG. XII/24. BOWLING HOOP



← L →

WELD PREPARATION MAY BE MADE FROM EITHER  
THE INSIDE OR OUTSIDE OF THE PLATE AT THE OPTION  
OF THE MANUFACTURER.



$W-T-\frac{1}{8}$  IN. BUT NOT LESS THAN  $\frac{1}{2}$  IN.

FIG. XII/26. DETAIL OF FLUE JOINT.





FIG. XII/27.



XII/28.

N.

FIG. XII/29.




FIG. XII/30

FOUNDATION RING.




FIG. XII/31 FIREHOLE MOUTHPIECE




FIG. XII/32. THROAT-PIECE






FIG. XII/33 ACCESS OPENING FOR WET-BACK BOILERS.


ATTACHMENT OF FIREBOX AND  
COMBUSTION CHAMBER STAYS.



C = 57


FIG. XII/35

C = 80


FIG. XII/36

C = 80

FIG. XII/37


ATTACHMENT OF BAR STAYS.

C = 85  
FIG. XII/38




C = 110  
FIG. XII/40

WASHERS TO BE CLOSELY  
BEDDED TO PLATES



C = 95,  
FIG. XII/39



C = 120  
FIG. XII/41




FIG. XII/42.




FIG. XII/43.




FIG. XII/44.

GIRDER MAY BE CARRIED  
OVER THE ENDS OF COMBUSTION  
CHAMBER OR FIREBOX.





FIG. XII/45.


TYPICAL METHODS OF FITTING WELDED  
GIRDERS TO WELDED COMBUSTION CHAMBERS  
AND FIREBOXES.



GIRDERS MAY BE SHAPED TO EITHER  
THE FULL OR DOTTED LINES AS  
SHOWN ABOVE.

FIG. XII/46.

PICAL METHOD OF FITTING WELDED GIRDERS  
TO WELDED COMBUSTION CHAMBERS, AND FIRE BOXES.







ALTERNATIVE FORGING MADE IN HALVES AND  
FUSION-WELDED ALONG X-X.



WELD PREPARATIONS  
AT X-X.

FIG. XII/47 FUSION WELDED OVAL MANHOLE FRAME

FIG. XII/48FIG. XII/49FIG. XII/50FIG. XII/51




FIG. XII/52. TYPICAL MILD STEEL DISTANCE PIECE FOR MOUNTINGS.




FIG XII/53 DETAILS OF TEST PLATES.

4.	TENSILE	TEST FOR SEAM.
2	IMPACT	TEST OUTER SURFACE OF PLATE.
2a & 2b	IMPACT	RE-TEST OUTER SURFACE OF PLATE.
5.	IMPACT	TEST INNER SURFACE OF PLATE.
3a & 3b	IMPACT	RE-TEST INNER SURFACE OF PLATE.
4.	TENSILE	TEST FOR ALL-WELD-METAL.
5.	NORMAL	BEND TEST-OUTER SURFACE IN TENSION.
6.	REVERSE	BEND TEST-INNER SURFACE IN TENSION.
7.	MICRO,	AND MACRO TEST.







FIG. XII/54. DETAILS OF TEST PLATES.

1. TENSILE TEST FOR SEAM.
2. IMPACT TEST OUTER SURFACE OF PLATE.
- 2a. IMPACT RETEST OUTER SURFACE OF PLATE.
- 2b. IMPACT TEST INNER SURFACE OF PLATE.
3. IMPACT RETEST INNER SURFACE OF PLATE.
- 3a. IMPACT RETEST ALL WELD METAL.
4. TENSILE TEST FOR ALL WELD METAL.
5. NORMAL BEND TEST - OUTER SURFACE IN TENSION.
6. REVERSE BEND TEST - INNER SURFACE IN TENSION.
7. MICRO AND MACRO TESTS.



SPECIMEN 1a TENSILE TEST FOR SEAM



SPECIMEN 1b TENSILE TEST FOR SEAMS (THICK PLATES)

$t$  = THICKNESS OF PLATE.

$b$  = BREADTH OF TEST PIECE.

SPECIMEN 1a NOT LESS THAN  $t$  AND IN NO CASE LESS THAN  $1\frac{1}{2}$  IN.



SPECIMEN 1b  $\geq b$  NOT LESS THAN  $1\frac{1}{2}$  IN.

$w$  = WIDTH OF WELD GROOVE.

$p$  = PARALLEL LENGTH, MINIMUM =  $3 \times w$ .


$r$  = RADIUS AT SHOULDER, MINIMUM =  $1\frac{1}{2}$  IN.

FIG. XII/55. TENSILE TEST PIECES




ENLARGED VIEW OF NOTCH.

SPECIMENS (2) AND (3) IMPACT TESTS


FIG. XII/56 IZOD IMPACT TEST PIECES

SPECIMEN 4 TENSILE TEST ALL WELD METAL



FIG. XII/57 TENSILE TEST PIECE. ALL-WELD METAL.

RADIUS  $P > 10$  PERCENT OF  $t$  (THICKNESS OF THE SPECIMEN)

A • NORMAL BEND SPECIMEN. ⑤




B • REVERSE BEND SPECIMEN ⑥

C • SPECIMENS ⑤ & ⑥  
CUT FROM SINGLE PIECE OF PLATE

CORNERS ROUNDED TO RADIUS, NOT EXCEEDING 10 PERCENT

SPECIMEN MOUNTED TO BEND TEST

FIG 158 BEND TEST



THESE PORTIONS TO BE RETAINED FOR POSSIBLE RETESTS.

1. TENSILE TEST FOR WELDED SEAM.
2. BEND TEST-OUTER SURFACE OF THE WELD IN TENSION.
3. BEND TEST-INNER SURFACE OF THE WELD IN TENSION.
4. NICK BREAK TEST.
5. MACRO AND MICRO TESTS.
- 6.

FIG. XI/59. DETAILS OF TEST PLATES.






FIG. XII/62. COMPENSATION FOR BRANCH



TUBES TO BE LIGHTLY EXPANDED INTO THE PLATE  
BEFORE WELDING.

C = 64 COLD END.  
C = 56 HOT END.


FIG. XII/63.



TUBES TO BE LIGHTLY EXPANDED INTO THE PLATE  
BEFORE WELDING.

C = 64 COLD END.  
C = 56 HOT END.


FIG. XII/64.




TUBES TO BE LIGHTLY EXPANDED INTO THE PLATE  
BEFORE WELDING

C = 80 COLD END  
C = 70 HOT END.

FIG. XII / 65.



TYPICAL ARRANGEMENT OF END PLATES ON LANCASHIRE BOILERS.



TYPICAL ARRANGEMENT OF END PLATES ON LANCASHIRE BOILERS.




FIG. XII/68.

SEE REG. 611 FOR  
VARIOUS METHODS OF ATTACHMENT OF  
END PLATES TO SHELL AND FURNACES.

TYPICAL ARRANGEMENT OF END PLATES ON CORNISH BOILERS.





FIG. XII / 69.

SEE REG. 611 FOR  
VARIOUS METHODS OF ATTACHMENT OF  
END PLATES TO SHELL AND FURNACES

TYPICAL ARRANGEMENT OF END PLATES ON CORNISH BOILERS.



TYPICAL ARRANGEMENT OF END PLATES ON ECONOMIC BOILERS.




FIG.XII/71

SEE REG. 611 FOR VARIOUS METHODS  
OF ATTACHMENT OF END PLATES  
TO SHELL AND FURNACES

TYPICAL ARRANGEMENT OF END PLATES ON ECONOMIC






FIG. XI/72

TYPICAL ARRANGEMENT OF END PLATES ON MULTITUBULAR BOILERS



YPICAL ARRANGEMENT OF END PLATES ON MULTITUBULAR BOILERS



FOR OTHER METHODS OF ATTACHMENT SEE FIG. XII/35, 36, & 37.

FIG XII/74. ARRANGEMENT OF FIREBOX CROWN  
STAYS FOR LOCO-TYPE BOILERS.




FIG. XII/75. ARRANGEMENT OF FIRE BOX CROWN AND TRANSVERSE STAYS FOR LOCO-TYPE BOILERS.






FIG. XII/76 BREATHING SPACE

( SEE RECOMMENDED BREATHING SPACES GIVEN IN  
REG. 656 )



NOTE :- THIS SKETCH IS DIAGRAMMATIC ONLY


ALL-WELDED GUSSET STAY.



SECTION A-A.

FIG. XII/77. TYPICAL DETAILS FOR ALL-WELDED GUSSET STAYS. (SEE REG. 657.)

WELDED AND PINNED GUSSET STAY.SECTION A.A.FIG. XII/78. TYPICAL DETAILS FOR WELDED & PINNED GUSSET STAY.SECTION B.B.







FIG. A.



MINIMUM WELD DIMENSIONS  
WHERE PLATE THICKNESS  $T_3$  IS  
LESS THAN  $1.5 T_m$




FIG. B.

FIG. C

FIG. XII(B) MINIMUM WELD ATTACHMENT FOR STANDPIPES UPTO AND  
INCLUDING 5 IN BORE NOT REQUIRING COMPENSATING  
PLATES

NOTE-- THE TYPES IN 'A' AND 'B' ARE ONLY PERMITTED WHERE THE ELECTRODES  
AND TECHNIQUE TO BE USED HAVE BEEN SHOWN BY SEPERATELY PREPARED  
TEST SPECIMENS TO GIVE FULL PENETRATION WITH SOUND WELD METAL  
& THE ROOT OF THE GROOVES.




FIG. A.




FIG. C

MINIMUM WELD DIMENSIONS  
WHERE PLATE THICKNESS  $T_s$  IS.  
LESS THAN  $1.5 T_h$ .

FIG. B

FIG. XIII/81 MINIMUM WELD ATTACHMENTS FOR STANDPIPES  
OVER 5' BORE NOT REQUIRING COMPENSATION PLATES.




FIG XII/82 MINIMUM WELD ATTACHMENT FOR STAND PIPES OVER 5" BORE  
REQUIRING COMPENSATION PLATES.




FIG XII/83 MINIMUM WELD ATTACHMENT FOR STAND PIPES OVER 5" BORE  
REQUIRING COMPENSATION PLATES.




FIG 'A'





FIG 'B'

FIG XII/84 MINIMUM WELD ATTACHMENTS FOR STANDPIPES UPTO  
AND INCLUDING 5 BORE REQUIRING COMPENSATION  
PLATES.

ALLOWANCE TO BE MADE  
FOR FINAL MACHINING  
AFTER WELDING.



THE FLANGE SHALL NOT BE A TIGHT FIT ON TO THE PIPE. THE MAXIMUM CLEARANCE BETWEEN THE BORE OF THE FLANGE AND THE OUTSIDE DIAMETER OF THE PIPE SHALL BE  $\frac{1}{8}$  IN AT ANY POINT AND THE SUM OF THE CLEARANCES DIAMETRICALLY OPPOSITE SHALL NOT EXCEED  $\frac{3}{16}$  IN.

FIG. XII/85. WELDED ON FLANGE.




FIG. A




FIG. B

FIG. XII/86. PADS WELDED ON FOR STUDS.




FIG. XII/87

THE TYPE SHOWN IN FIG.XII/87 SHALL NOT BE  
USED WHERE THICKNESS OF THE SHELL  
EXCEEDS  $\frac{3}{4}$  IN.




FIG.XII/88

THE TYPE SHOWN IN FIG XII/88 TO BE USED  
WHEN SHELL THICKNESS EXCEEDS  $\frac{3}{4}$  IN

## APPENDIX A

RECOMMENDED FORMS OF WELD PREPARATION (MODIFIED)

DETAILS L-P INCLUSIVE ARE SUITABLE FOR MANUAL WELDING AND NORMAL AUTOMATIC WELDING WHERE THE AUTOMATIC DEEP PENETRATION TECHNIQUE IS EMPLOYED, SOME MODIFICATION MAY BE NECESSARY.

## L SINGLE J BUTT WELD.

WELD DETAIL.	WELDING POSITION	THICKNESS 'T'	GAP* G	ANGLE ° OC	RADIUS R	ROOT FACE R.
WELDED FROM BOTH SIDES OR ONE SIDE ONLY.	ALL POSITION OVER $\frac{1}{2}$	IN	IN	10-20°	$\frac{3}{8}-\frac{3}{16}$	$\frac{1}{16}-\frac{1}{8}$

## M DOUBLE J BUTT WELD

WELD DETAIL	WELDING POSITION	THICKNESS 'T'	GAP* G	ANGLE ° OC	RADIUS R	ROOT FACE R.
WELDING FROM BOTH SIDES	ALL POSITIONS OVER 1	IN	IN	10-20°	$\frac{3}{8}-\frac{3}{16}$	$\frac{1}{16}-\frac{1}{8}$

## N SINGLE BEVEL BUTT WELD.

WELD DETAIL	WELDING POSITION	THICKNESS 'T'	GAP G	ANGLE ° OC	ROOT FACE R
WELD FROM BOTH SIDES OR FROM ONE SIDE ONLY.	ALL POSITIONS OVER $\frac{3}{16}-\frac{3}{8}$	IN	IN	45-50°	$0-\frac{1}{16}$

## P DOUBLE BEVEL BUTT WELD.

WELD DETAIL	WELDING POSITION	THICKNESS 'T'	GAP G	ANGLE ° OC	ROOT FACE R
WELDED FROM BOTH SIDES	ALL POSITION OVER $\frac{1}{2}$	IN	IN	45-50°	$0-\frac{1}{16}$

THE USE OF THE MIN. GAP AND MIN. ANGLE SHOULD BE ASSOCIATED WITH THE MAX. RADIUS R OF  $\frac{3}{8}$  IN. CONVERSELY, THE MAX. GAP AND MAX. ANGLE SHOULD BE ASSOCIATED WITH THE MIN. RADIUS R OF  $\frac{3}{16}$  IN.

